

DAILY  
REMINDER


1968

# Language Way

## Editorial Department

KCSlip4 67878

SEA435969



KCslip4 67879

SEA435970

NAME

ADDRESS

TEL.

Monday, January 1, 1968

1st day - 365 days follow

New Year's Day

11:00 am

Checked station out

# 1 2 & 3 running

water level 4'

D.O. Hartford

2:00

# 1 2 & 3 running

water level 3 4'

D.O. Hartford

KCslip4 67880

SEA435971

Tuesday, January 2, 1968

2nd day - 364 days to follow

8:30 AM

Checked Station

#1 & #2 pumps running  
#3 pump in standby  
Water level 3.6'

Clarence W. Walker

3:00 PM

Checked Station

#1 & #2 pumps running  
#3 pump turned off.  
Water level 7.0'

Clarence W. Walker

Wednesday, January 3, 1968

3rd day - 363 days to follow

8:40 AM

Checked Station

#1 & #2 pumps running  
#3 pump off. High wet well  
at Disag. plant  
Water level 8.3'

Clarence W. Walker

1:55 PM Checking station #1 pump  
hot - Plugged with rags? Ed Wargan

3:15 PM

Removed rags and stuck from  
#1 pump - 1 handful.

#1 & #2 pumps running  
#3 pump off  
Water level 5.4'

Clarence W. Walker

KCslip4 67881

SEA435972

Thursday, January 4, 1968

4th day - 362 days to follow

8:40 AM

Checked station

#1 + #2 pumps running  
#3 off - Turned pump on  
Water level 6.6 feet

Jim Lea

5:30 PM

Checked station

#1 + #2 + #3 pumps running  
Turned off #3 pump  
Water level 4.0 feet

Jim Lea

Friday, January 5, 1968

5th day - 361 days to follow

8:15

Checked station

#1 + #2 pumps running  
#3 off - Turned pump on  
Water level 6.6 feet

Ray Moore

F K Of Ws - I L I  
F G d m - Igda & Assoc.

2:25 P.M.

Checked station

pumps #1 + #2 + #3 running  
Turned off #3 pump  
Water level 3.8 feet

Ray Moore

KCslip4 67882

SEA435973

Saturday, January 6, 1968

6th day - 360 days to follow

5:30 AM Epiphany

Checked Station

#1 & #2 pumps running  
#3 pump off - turned to Auto  
Water level 6.4'

Clarence W. Walker

Sunday, January 7, 1968

7th day - 359 days to follow

9:00 AM

Checked Station

#1 & #2 pumps running  
#3 pump off - turned to Auto  
Water level 6.6'

Clarence W. Walker

3:00 PM

Checked Station

#1 & #2 pumps running  
#3 pump - turned off  
Water level 3.4'

Clarence W. Walker

2:55 PM

Checked Station

All pumps running  
Water level 5.6'  
Turned #3 pump off

Clarence W. Walker

KCSlip4 67883

SEA435974

Monday, January 8, 1968

8th day - 358 days to follow

8:30 A.M.

Battle of New Orleans

Checked station

#1 & #2 running

Turned #3 on ✓

Water level 4.2 ft.

John Lee

2:55 p.m.

Checked station

#1 & #2 & #3 pump running

Turned #3 pump off

water level 3.8 ft

Roy Moore

Tuesday, January 9, 1968

9th day - 357 days to follow

8:30 A.M.

Checked station

#1 & #2 pump running

Turned #3 on

water level 11.6 ft

Roy Moore

2:50 p.m.

Checked station

#1 & #2 pump running

#3 pump turned off early due to

rise in wet well

water level 11.6 ft

Roy Moore

KCslip4 67884

SEA435975

Wednesday, January 10, 1968

10th day - 356 days to follow

8:30 A.M.

Checked station  
#1 + #2 pumps running  
Turned #3 on  
water level 6.6 ft

Ray Moore

1:30 P.M.

Checked station  
water level 5.8 feet  
All pumps running  
to design

2:50 p.m.

Checked station  
#1 + #2 + #3 pumps running  
Turned #3 pump off  
water level - 3.8 ft

Ray Moore

Thursday, January 11, 1968

11th day - 355 days to follow

10:30 A.M.

Checked station  
#1 + #2 pumps running  
Turned #3 off  
water level 6.6 ft

Ray Moore

2:50 p.m.

Checked station  
#1 + #2 + #3 pumps on  
Turned #3 off  
water level 3.6 ft

Ray Moore

KCSlip4 67885

SEA435976

Friday, January 12, 1968

12th day - 354 days to follow

8:20 A.M.

Checked station  
#1 + #2 pumps on  
Turned #3 on  
Water level 6.6 ft

Ray Moore

Saturday, January 13, 1968

13th day - 353 days to follow

9:00 AM

Checked station  
#1 + #2 pumps running  
Turned #3 pump on ✓  
Water level 11.2 feet

Jim Lee

2:50 p.m.

Checked pumping station  
#1 - #2 + #3 running  
#3 pump running hot  
Turned #3 off. Cleared pump <sup>removed sheet</sup>  
water level 6.8 ft

Ray Moore

3:15 PM

Checked station  
#1 - #2 + #3 pumps running  
Turned #3 off  
Water level 5.4 feet

Jim Lee

KCslip4 67886

SEA435977

Sunday, January 14, 1968

14th day - 352 days to follow

8:45 AM

Checked station

#1, #2 pump running

Turned #3 pump on

Water level 11.0 feet

Pump station completely surrounded  
by water and seeping into building

Jim Lea

Monday, January 15, 1968

15th day - 351 days to follow

8:15 A.M.

Checked station

~~#1, #2~~ + #3 pump on

Turned #1 pump on

Water level 11 ft.

Pump station surrounded by  
water

Ray Moore

3:00 PM

Checked station

#1, #2, #3 pumps running

~~Turned off~~ #3 pump on

Water level 5.0 feet

Jim Lea

2:30 P.M.

Checked Station

#1, #2 + #3 pumps on

Turned #3 off

Water level 5.0 ft.

Ray Moore

KCSlip4 67887

SEA435978

Tuesday, January 16, 1968

16th day - 350 days to follow

8:15 A.M.

Checked station  
#1 + #2 pumps running  
Turned #3 on

water level - 6.8 ft  
Water still outside station

Ray Moore

4:55 p.m.

Checked station  
#1 + #2 + #3 pumps running  
Turned #3 off  
water level 2.8 ft

Ray Moore

Wednesday, January 17, 1968

17th day - 349 days to follow

8:05 A.M.

Benjamin Franklin's Birthday

Checked station  
#1 + #3 pumps running

Turned #3 on

Water outside station going down  
Water level - 6.4 ft

Ray Moore

3:10 p.m.

Checked station  
#1 + #2 + #3 pumps on  
Turned #3 off  
Water level - 2.6 ft

Ray Moore

KCslip4 67888

SEA435979

Thursday, January 18, 1968

18th day - 348 days to follow

8:05 A.M.

Checked station  
#1 + #2 pumps running  
Turned #3 pump on  
Water level - 6.0 ft

Ray Moore

3:15 P.M.

Checked station  
#1 - #2 + #3 pumps on  
Turned #3 off  
Water level - 3.4 ft

Ray Moore

Friday, January 19, 1968

19th day - 347 days to follow

8:07 A.M.

Checked station  
#1 + #2 pumps on  
Turned #3 on  
Water level - 11.4 ft

Ray Moore

3:30 PM

Checked station  
#1 - #2 - #3 pumps on  
Turned #3 off  
Water level 6.4 feet

John Lee

KCslip4 67889

SEA435980

Saturday, January 20, 1968

20th day - 346 days to follow

9:00 AM Heavy Rain  
Checked Station  
#1 & #2 pumps running  
#3 off - High wet well  
Water level 8.2'

Clarence W. Walker

3:00 PM Heavy Rain  
Checked Station  
#1 & #2 pumps running  
#3 pump off  
Water level 9.0'

Clarence W. Walker

Sunday, January 21, 1968

21st day - 345 days to follow

9:30 AM  
Checked Station  
#1 & #2 pumps running  
#3 turned on auto - running  
Water level 7.4'

Clarence W. Walker

3:15 PM  
Checked Station  
#1 & #2 pumps running  
#3 on stand by  
Water level 9.8'  
Turned #3 pump off

Clarence W. Walker

KCSlip4 67890

SEA435981

Monday, January 22, 1968

22nd day - 344 days to follow

8:30 A.M.

Checking station

#1 + #2 running

Pump #3 back in service

Water level 8.5'

E.W. Dwyer

8:45 A.M.

Pumping water from around  
the station with the Midland  
pump.

E.W. Dwyer

2:50 P.M.

Checked station

\*#1 + #2 + #3 pumps on

Turned #3 pump off

Water level - 3.2 ft

Ray Moore

Tuesday, January 23, 1968

23rd day - 343 days to follow

8:15 A.M.

Checked station

#1 + #2 pumps running

Turned #3 pump on

Water level - 6.0 ft

Ray Moore

12:45 P.M.

G.M. Jones, Brown & Caldwell

Jack Gray, Mansourine Board

Visiting station.

3:00 P.M.

Checked station

\*#1 + #2 + #3 pumps on

Turned #3 off

Water level - 2.8 ft

Ray Moore

KCSlip4 67891

SEA435982

Wednesday, January 24, 1968

24th day - 342 days to follow

5:50 A.M.

Checked station  
pumps #1 & #2 running  
Turned #3 on  
Water level - 6.0 ft

By Moore

5:00 P.M.

Checked station  
#1 - #2 + #3 pumps running  
Turned #3 off.  
Water level - 3.4 ft.

By Moore

Thursday, January 25, 1968

25th day - 341 days to follow

8:40 A.M.

Checked station  
#1 + #3 pumps running  
Turned #2 on  
Water level - 6.0 ft

By Moore

3:00 P.M.

Checked station  
#1 - #2 + #3 pumps running  
Turned #3 off  
Water level - 3.4 ft

By Moore

KCSlip4 67892

SEA435983

Friday, January 26, 1968

26th day - 340 days to follow

8:25 A.M.

Checked station

#1 & #2 pumps running

#3 pump running hot

Turned #3 on & #3 off to check  
pump. Cleaned rag & a stick  
out of #1.

#1 pump real hot - had to  
leave face plate off so it  
cooled

J. Morgan  
L. Moore.

11:30 A.M.

Put #1 pump together & primed

Jim Lee

3:00 P.M.

Checked station

#1 - #2 & #3 pumps running

Turned #3 off

Water level - 6.4 ft

R. Moore

Saturday, January 27, 1968

27th day - 339 days to follow

8:00 AM

Checked station

#1 & #2 pumps running

Turned #3 pump on

Water level 6.2 feet

Jim Lee

3:00 PM

Checked station

#1 - #2 - #3 pump running

Shut #3 off

Water level 4.0 feet

Jim Lee

KCslip4 67893

SEA435984

Sunday, January 28, 1968

28th day - 338 days to follow

9:15 AM

Checked station  
#1 & #2 pumps running  
Turned off #3 pump  
Water level 7.0 feet

Jim Lee

3:00 PM

Checked station  
#1 & #2 & #3 pumps running  
Shut off #3 pump  
Water level 4.0 feet

Jim Lee

Monday, January 29, 1968

29th day - 337 days to follow

8:10 AM

Checked station  
#1 & #3 pumps running  
Turned off #2 pump  
Water level - 6.8 ft

Ray Moore

3:00 P.M.

Checked station  
#1 - #2 & #3 pumps running  
Turned off 3 pumps off  
Water level - 4.0 ft

Ray Moore

KCslip4 67894

SEA435985

Tuesday, January 30, 1968

30th day - 336 days to follow

8:05 A.M.

Checked station  
#1 + #2 pumps running  
Turned #3 on  
Water level - 6.8 ft

By Moore

1:00 P.M.

Turned #3 pump off because  
water too high in wet well

By Moore

1:30 P.M. Checking water level 4'3"

To begin

3:00 P.M.

Checked station  
#1 + #2 pumps running  
Water level - 6.8 ft

By Moore

Wednesday, January 31, 1968

31st day - 335 days to follow

Last day for employers to file quarterly Social Security Tax Return  
and Wage Report, covering three previous calendar months.

8:15 A.M.

Checked station  
#1 + #2 pumps off  
Turned #3 on  
Water level - 7.2 ft

By Moore

3:10 P.M.

Checked station  
#1 + #2 + #3 pumps on  
Turned #3 off  
Water level - 5.8 ft

By Moore

KCslip4 67895

SEA435986

Thursday, February 1, 1968

32nd day - 334 days to follow

8:30 A.M.

Checked station  
#1 + #2 pumps on  
Turned #3 on  
Water level - 7.0 ft

By Mac

3:00 P.M.

Checked station  
#1 - #2 + #3 pumps running  
Turned #3 off  
Water level - 3.8 ft

By Mac

Friday, February 2, 1968

33rd day - 333 days to follow

1:25 A.M.

Checked station  
#1 + #2 pumps on  
Turned #3 on  
Water level - 11.8 ft

By Mac

2:50 P.M.

Checked station  
#1 - #2 + #3 pumps on  
Turned #3 off  
Water level - 4.2 ft

By Mac

KCslip4 67896

SEA435987

Saturday, February 3, 1968

34th day - 332 days to follow

900 AM

Checked Station

#1 & #2 pumps running

Turned on #3

Water Level 11.6'

Clarence W. Walker

3:00 PM

Checked Station

All Three pumps running

Turned #3 off

Water 4.5'

Clarence W. Walker

Sunday, February 4, 1968

35th day - 331 days to follow

845 AM

Checked Station

Water around Building and  
coming in door (very little wind)

#1 & #2 pumps running

Turned on #3

Water level 11.8'

Clarence W. Walker

2:45 PM

Checked Station

Water level around outside of  
Building is much lower,

All Three pumps running

Turned #3 off

Water level 5'

Clarence W. Walker

KCslip4 67897

SEA435988

Monday, February 5, 1968

36th day - 330 days to follow

8:10 A.M.

Checked station

#1 & #2 pumps running

Turned #3 off

Water going down around station

Water level - 8.4 ft

Roy Moore

3:00 P.M.

Checked station

#1 - #2 + #3 pumps running

Turned #3 off

Water level - 3.2 ft

Roy Moore

Tuesday, February 6, 1968

37th day - 329 days to follow

8:00 A.M.

Checked station

#1 + #2 pumps running

Turned #3 off

Water level - 6.4 ft

Roy Moore

3:15 PM

Checked station

#1 - #2 - #3 pumps running

Turned #3 off

Water level

3.2 feet

Jim La

KCslip4 67898

SEA435989

Wednesday, February 7, 1968

38th day - 328 days to follow

8:15 A.M.

Checked station  
#1 + #2 pumps running  
Turned #3 off  
Water level — 6.3 ft.

Roy Moore

2:40 P.M.

Checked station  
#1, #2 & #3 pumps running  
Turned #3 pump off  
Water level — 2.6 ft

Roy Moore

Thursday, February 8, 1968

39th day - 327 days to follow

8:30 A.M. Checked station  
#1 + #2 Running  
water level 6 feet  
T. W. Langford

2:00 P.M.

Checking water level 3.5 feet  
T. W. Langford

3:00 P.M.

Checked station  
#1 - #2 & #3 pumps running  
Turned #3 off  
Water level — 2.3 ft

Roy Moore

KC Slip 4 67899

SEA435990

Friday, February 9, 1968

40th day - 326 days to follow

9:00 AM

Checking Station  
#1 & #2 pumps running  
Turned #3 pump on  
Water level 5'

Clarence M. Walker

3:00 P.M.

Checked station  
#1 - #2 + #3 pumps running  
Turned #3 pump off.  
Water level - 4 ft

Ray Moore

Saturday, February 10, 1968

41st day - 325 days to follow

1:30 PM

Checked station  
#1 - #2 - #3 pumps running  
Turned #3 off  
Water level 2.6 feet

Jim Lee

3:00 PM

Checked station  
#1, #2 pumps running  
Water level 6.0 feet

Jim Lee

KCslip4 67900

SEA435991

Sunday, February 11, 1968

42nd day - 324 days to follow

7:30 AM

Edison's Birthday

Checked station  
#1, #2, #3 running  
Turned #3 on  
Water level 6.0 feet

Jim Lee

3:15 PM

Checked station  
#1, #2, #3 running  
Shut #3 off  
Water level 3.0 ft.

Jim Lee

Monday, February 12, 1968

43rd day - 323 days to follow

7:30 AM

Lincoln's Birthday

Checked station  
#1, #2 running  
Turned #3 on  
Water level 6.0 ft

Jim Lee

3:20 PM

Checked station  
#1, #2, #3 running  
Turned #3 off  
Water level 2.2 feet

Jim Lee

KCSlip4 67901

SEA435992

Tuesday, February 13, 1968

44th day - 322 days to follow

8:30 A.M. Checked station  
water level 8 feet  
Put #3 pump back on line.  
#1 & #3 pumps operating.  
checked oil levels All OK!

E. Dargan

3:30 P.M. Checked Station  
#1 & 2 on line & off manually  
water level 8 feet.

E. Dargan

Wednesday, February 14, 1968

45th day - 321 days to follow

Valentine's Day

8:05 A.M.

Checked station  
#1 & #2 pumps running  
Turned #3 pump off  
Water level - 6.0 ft

Pay Moore

3:25 P.M.

Checked station  
#1 & 2 pumps on  
#3 off automatically  
Turned #3 off  
Water level - 4 ft

Pay Moore

KCSlip4 67902

SEA435993

Thursday, February 15, 1968

46th day - 320 days to follow

8:00 A.M.

Checked station

#1 & #2 pumps running

Turned #3 on

Water level - 5.8 ft

Ray Moore

3:10 P.M.

Checked station

#1 - #2 & ~~3~~ pumps running

Turned #3 off from ~~3~~ Auto-off

Water level - 3.4 ft

Ray Moore

Friday, February 16, 1968

47th day - 319 days to follow

8:15 A.M.

Checked station

#1 & #2 pumps running

Turned #3 on

Water level - 5.6 ft

Ray Moore

9:15 A.M. Checking Station

#~~1~~ & #3 pumps running water low  
at 3.5"

Checked oil level - OK

E. Longson

3:00 P.M.

Checking Station

#1 & 2 pumps running

#3 pump turned off

Water level 3.8 ft

Clarence W. Walker

KCSlip4 67903

SEA435994

Saturday, February 17, 1968

48th day - 318 days to follow

8:30 A.M.

Checked station  
#1 + #2 pumps running  
Turned #3 pump on  
Water level — 5.6 ft

Ray Moore

3:15 P.M.

Checked station  
#1 + #2 pumps on  
#3 on auto off  
Turned #3 off  
Water level — 3.0 ft

Ray Moore

Sunday, February 18, 1968

49th day - 317 days to follow

8:00 A.M.

Checked station  
#1 + #2 pumps running  
Turned #3 pump on  
Water level — 16.0 ft

Ray Moore

3:00 P.M.

Checked station  
#1 + #2 + #3 pumps on  
Turned #3 off  
Water level — 4.8 ft

Ray Moore

KCSlip4 67904

SEA435995

Monday, February 19, 1968

50th day - 316 days to follow

8:30 AM

Checking Station

#1 & #2 pumps running

Turned #3 pump to auto-running

Water level 11.2'

Clarence W. Walker

3:30 PM

Checking Station

All pumps running

Turned #3 pump off

Water level 4.6'

Clarence W. Walker

Tuesday, February 20, 1968

51st day - 315 days to follow

8:45 AM

Checking Station

#1 & #3 pumps running

Turned #2 on

Water level 6.0 feet

Jim Lee

3:15 PM

Checking Station

#1 & #2 pumps running

Turned #3 pump off

Water level 2.18'

Clarence W. Walker

KCslip4 67905

SEA435996

Wednesday, February 21, 1968

52nd day - 314 days to follow

8:10 A.M.

Checked station

#1 & #2 pumps running

Turned #3 pump off  
Water level — 9.6

1:15 P.M. Roy Moore  
Shut pumps off To clean out  
intake

Jim Lee

5:00 P.M.

Put station back in service.

E.W. Young

3:25 P.M.

Checked station

#1-#2 & #3 pumps running

Turned #3 pump off

Water level — 3.6 ft

Roy Moore

Thursday, February 22, 1968

53rd day - 313 days to follow

8:00 A.M.

Washington's Birthday

Checked station

#1 & #2 pumps running

Turned #3 pump off  
Water level — 6.8 ft

Roy Moore

2:45 P.M.

Checked station

Water rising around station

#1-#2 & #3 pumps running

Turned #3 pump off

Water level — 2.4 ft

Roy Moore

KCSlip4 67906

SEA435997

Friday, February 23, 1968

54th day - 312 days to follow

8:05 A.M.

Checked station  
Water has risen up to the door  
#1 + #2 pumps running  
Turned #3 pump on  
Water level — 10.2 ft

Roy Moore

3:00 P.M.

Checked station  
water coming in window  
#1 + #2 + #3 pumps running  
Water level — 3.8 ft  
Turned #3 pump off.

Roy Moore

Saturday, February 24, 1968

55th day - 311 days to follow

8:05 A.M.

Checked station  
Water surrounding station  
#1 + #2 pumps running  
Turned #3 pump on  
Water level — 8.6 ft

Roy Moore

3:00 P.M.

Checked station  
Water still up around station  
#1 - #2 + #3 pumps on  
Turned #3 pump off  
Water level — 3.2 ft

Roy Moore

KCSlip4 67907

SEA435998

Sunday, February 25, 1968

56th day - 310 days to follow

7:00 A.M.  
Checked Station  
Water up to station door  
#1 & #2 pumps running  
Water level 4.6'

Clarence W. Walker

3:05 P.M.  
Checked Station  
Pumps running  
#3 turned off  
Water Level 3.6'

Clarence W. Walker

Monday, February 26, 1968

57th day - 309 days to follow

8:05 A.M.  
Checked station  
Water up to door  
#1 & #2 pumps running  
Turned #3 pump on  
Water level - 5.8 ft

Roy Moore

3:00 P.M.  
Checked station  
#1 - #2 & #3 pumps running  
Turned #3 pump off  
Water level - 3.4 ft

Roy Moore

KCslip4 67908

SEA435999

Tuesday, February 27, 1968

58th day - 308 days to follow

8:05 A.M.

Checked station  
#1 + #2 pumps running  
Turned #3 pump on  
Water level - 5.6 ft

Ray Moore

3:00 P.M.

Checked station  
#1 + #2 + #3 pumps running  
Turned #3 pump off  
Water level - 5.6 ft

Ray Moore

Wednesday, February 28, 1968

59th day - 307 days to follow

8:15 A.M.

Ash Wednesday

Checked station  
#1 + #2 pumps running  
Turned #3 pump on  
Water level - 5.6 ft

Day 1 Moore

3:30 P.M.

Checked Station  
#1 + #2 pumps running  
Water level 2.4'  
Turned #3 pump off

Clarence W. Walker

KC Slip 4 67909

SEA436000

Thursday, February 29, 1968

60th day - 306 days to follow

8:10 A.M.

Checked station  
#1 & #2 pumps running  
Turned #3 pump on  
Water level — 5.6 ft.

Ray Moore

9:00 A.M. Checking Station  
Water level 3.3 ft.

F. Wagner

3:10 P.M.

Checked station  
#1 - #2 & #3 pumps running  
Turned #3 pump off  
Water level — 3.0 ft

Ray Moore

Friday, March 1, 1968

61st day - 305 days to follow

8:10 A.M.

Checked station  
#1 & #2 pumps running  
Turned #3 pump on  
Water level — 5.4 ft

Ray Moore

3:10 P.M.

Checked station  
#1 - #2 & #3 pump running  
Turned #3 pump off  
Water level — 3.2 ft

Ray Moore

KC Slip 4 67910

SEA436001

Saturday, March 2, 1968

62nd day - 304 days to follow

9:15 AM

Checked station  
#1 & #2 pumps running  
Turned #3 on  
Water level 5.2 feet

Jim Lea

3:15 PM

Checked station  
#1 & #2 pumps running  
Turned #3 off  
Water level 3.5 feet

Jim Lea

Sunday, March 3, 1968

63rd day - 303 days to follow

8:50 AM

First Sunday of Lent

Checked station  
#1 & #2 running  
Water level 5.4 feet

Jim Lea

3:15 PM

Checked station  
#1 & #2 pumps running  
Water level 5.6 feet

Jim Lea

KCslip4 67911

SEA436002

Monday, March 4, 1968

64th day - 302 days to follow

Checking station Running hard  
8:30 A.M.  
#1 & #2 running #3 off due to  
#3 sewage pump being  
required at diagonal valley pump  
~~station~~  
water level 7'8"  
Takwagan

3:45 P.M.

Checking station  
#1 & #2 pumps running  
#3 pump off  
Water level 5.8'

Clarence W. Walker

Tuesday, March 5, 1968

65th day - 301 days to follow

Checking station - 8:30 A.M.  
#1 & #2 pumps running  
Surge #3 pump on  
Water level - 6.0 ft

Duty place  
Dave Roddey

3:00 P.M.

CHILLING STATION  
#1 AND #2 PUMPS RUNNING  
#3 PVAP AUTO OFF  
TOURN #3 OFF  
WATER LEVEL 4'

Dave Roddey  
Roy Moore

KCSlip4 67912

SEA436003

Wednesday, March 6, 1968

66th day - 300 days to follow

CHECKING STATION  
PUMPS #1 AND #2 RUNNING

PUMP #3 OFF

TURNING #3 ON

WATER LEVEL = 5'8"

Dave Rodley  
Day Moore

8:30 A.M.

Thursday, March 7, 1968

67th day - 299 days to follow

8:30 A.M.

Checked station  
#1 & #2 pumps running

Turned #3 pump on  
Water level - 5.8 ft

Day Moore

Checking Station 5:35 P.M.

Water level 5'5" feet  
oil level on gauge 0.2

Cleaning debris from around  
station

Lift #3 pump off and out of  
service

E. Morgan

CHECKING STATION

2:45 P.M.

WATER LEVEL 4FT.

#1, 2, 3, Running  
Turning #3 OFF

Dave Rodley

KC Slip 4 67913

SEA436004

Friday, March 8, 1968

68th day - 298 days to follow

CHECKING STATION 8:15 A.M.

PUMPS #1 AND #2 RUNNING

TURNED #3 PUMP OFF

WATER LEVEL = 5'8"

Dave Rodley

10:5 P.M.

Checking station

Water level 5'5"

Tell Rogers

3:15 P.M.

CHECKING STATION

#1, 2, 3 PUMPS RUNNING

WATER LEVEL = 3'4"

TURNING #3 PUMP OFF

Dave Rodley

Saturday, March 9, 1968

69th day - 297 days to follow

8:10 A.M.

Checked station

#1 & #2 pumps running

Turned #3 pump on

Water level - 5.8 ft

Ray Moore

3:00 P.M.

Checked station

#1 - #2 & #3 pumps running

Turned #3 pump off

Water level - 3.2 ft

Ray Moore

KCslip4 67914

SEA436005

Sunday, March 10, 1968

70th day - 296 days to follow

Second Sunday of Lent

8:25 A.M.

Checked station

#1 & #2 pumps running

Turned #3 pump on  
Water level — 5.8 ft

Ray Moore

3:25 P.M.

Checked station

#1 & #2 & #3 pumps running

Turned #3 pump off  
Water level — 5.8 ft

Ray Moore

Monday, March 11, 1968

71st day - 295 days to follow

8:10 A.M.

Checking station

#1 and #2 pumps running

Turned #3 pump on

Water level — 6 ft.

Oil level on pumps OK.

Dave B. Miller

10:30 A.M. Checking station

Water level 3.5"

Starting to rain - off #3 pump

off

Ed Kibbey

3:00 P.M.

Checked station

#1 & #2 pumps running

Water level — 6.2 ft

Ray Moore

KCslip4 67915

SEA436006

Tuesday, March 12, 1968

72nd day - 294 days to follow

8:20 A.M.  
CHECKING STATION  
PUMPS #1 AND #2 RUNNING  
TURNED #3 PUMP ON  
WATER LEVEL - 10.2 FT.

Dave Rosing

1440 -  
Inspecting station  
Rummel - Mobley

3:15 P.M.

Checked station  
#1 & #2 pumps running  
#3 pump off automatically  
Turned #3 pump off Man.  
Water level - 3.3 ft

Davy Moore

Wednesday, March 13, 1968

73rd day - 293 days to follow

Last of Esther

7:50 A.M. Checking station  
Water level 5.5"  
Alarmed #3 to #1 off. Turned on

8:45 A.M. CHECKING STATION  
PUMPS #2 AND #3 RUNNING  
PUMP #3 OFF  
TURNED #1 PUMP ON. TURNED #1 PUMP OFF  
WATER LEVEL - 6 FT.

Dave Rosing

3:35 P.M.

Checked station  
#2 & #3 pumps running  
#1 pump off  
Water level - 6.0 ft

Davy Moore

KCslip4 67916

SEA436007

Thursday, March 14, 1968

74th day - 292 days to follow

Purim

8:23 A.M.  
CHECKING STATION  
PUMPS #2 AND #3 RUNNING  
PUMP #1 OFF  
WATER LEVEL - 6 FT.

Dave Roddy

3:15 P.M.

Checked station  
#2 & #3 pumps running  
#1 pump off  
Water level - 5.8 ft

Roy Moore

Friday, March 15, 1968

75th day - 291 days to follow

Shushan Purim

8:45 A.M.  
CHECKING STATION  
PUMPS #2 AND #3 RUNNING  
PUMP #1 OFF  
WATER LEVEL - 8.2 FT.

Dave Roddy

11:45 A.M.  
CHECKING STATION  
WATER LEVEL - 9 FT.  
TURNED #1 PUMP ON  
DAVE RODDY

3:36 P.M.  
CHECKING STATION  
PUMPS #1, 2, 3 RUNNING  
TURNED #1 OFF  
WATER LEVEL - ~~9~~ 3.2 FT.

Dave Roddy

KCslip4 67917

SEA436008

Saturday, March 16, 1968

76th day - 290 days to follow

9:00 AM

Checking Station

#2 & #3 pumps running  
#1 pump turned off  
Water level 8.6'

Clarence W. Walker

10:50 AM

Checking Stat. no.

#2 & #3 pumps running  
#1 pump turned off  
Water level 9.8'

Clarence W. Walker

Sunday, March 17, 1968

77th day - 289 days to follow

Third Sunday of Lent

St. Patrick's Day

8:45 AM

Checking Station

#2 & #3 pumps running  
#1 pump turned off  
Water level 5.2'

Clarence W. Walker

3:10 PM

Checking Stat.

#2 & #3 pumps running  
#1 pump turned off  
Water level 5.6'

Clarence W. Walker

KC Slip 4 67918

SEA436009

Monday, March 18, 1968

78th day - 288 days to follow

7:00 A.M.

Checking station  
#2 and #3 pumps running  
#1 pump off  
Water level - 5.6 ft.  
Oil level on pumps OK.

Dave Riddle

3:15 P.M.

Checking station  
#2 & #3 pumps running  
#1 pump off  
Water level - 5.4 ft.

Ray Moore

Tuesday, March 19, 1968

79th day - 287 days to follow

8:05 A.M.

Checked station  
#2 & #3 pumps running  
#1 pump off  
Water level - 5.6 ft

Ray Moore

3:20 P.M.

Checked station  
#2 & #3 pumps running  
#1 pump off  
Water level - 5.6 ft

Ray Moore

KCSlip4 67919

SEA436010

Wednesday, March 20, 1968

80th day - 286 days to follow

8:55 A.M.

CHECKED STATION

PUMPS #2 AND #3 RUNNING

PUMP #1 OFF

WATER LEVEL - 5.6 FT.

Dave Roddey

9:05 P.M. Checking Station

water level 5'6"

checked oil level on 1.3-3  
generators - OK.

Tom Jagger

3:15 P.M.

CHECKING STATION

PUMPS #2 AND #3 RUNNING.

PUMP #1 OFF

WATER LEVEL - 5'6"

Dave Roddey

Thursday, March 21, 1968

81st day - 286 days to follow

9:00 A.M.

CHECKING STATION

PUMPS #2, 3 ON

PUMP #1 OFF

WATER LEVEL - 5.6 FT.

Dave Roddey

11:05 A.M.

Checking station

Ed Morgan

3:35 P.M.

CHECKING STATION

PUMPS #2 AND #3 RUNNING

PUMP #1 OFF

WATER LEVEL 5.6 FT.

Dave Roddey

KCSlip4 67920

SEA436011

Friday, March 22, 1968

82nd day - 284 days to follow

8:25 AM.

Checking station

PUMPS #2, #3 RUNNING

PUMP #1 OFF

WATER LEVEL - 5.6 FT.

CHECKED AIR LEVEL IN PUMPS #1, 2, 3. O.K.

Dave Rodley

C.V. Gibbs & P.J. Blank in  
station @ 1255.  
Pumps 2 & 3 running

Sewage being discharged  
from City storm drain to  
river.

City

11:5 PM.

Checking station

Tuckwagam

3:10 PM.

Checking station

PUMPS #2, #3 RUNNING

PUMP #1 OFF

WATER LEVEL - 5.6 FT.

Dave Rodley

Saturday, March 23, 1968

83rd day - 283 days to follow

8:00 A.M.

Checking station

#2 & #3 pumps running

#1 pump off

Water level - 5.8 ft

Roy Moore

3:00 P.M.

Checked station

#2 & #3 pumps running

#1 pump off

Water level - 5.8 ft

Roy Moore

KCslip4 67921

SEA436012

Sunday, March 24, 1968

84th day - 282 days to follow

Fourth Sunday of Lent

8:00 A.M.

Checked station

#2 & #3 pumps running

#1 pump off

Water level - 5.8 ft.

Dave Reddick

3:00 P.M.

Checked station

#2 & #3 pumps running

#1 pump off

Water level - 5.8 ft

Dave Reddick

Monday, March 25, 1968

85th day - 281 days to follow

8:35 A.M.

CHECKED STATION

PUMPS #2, #3 RUNNING

PUMP #1 OFF

#1 PUMP TURNED ON

F2 PUMP NOW OFF PUMP

WATER LEVEL - 8.1 FT

CHECKED OIL LEVEL ON #1, #2, #3 PUMPS - O.K.

Dave Reddick

10:50 A.M.

TURNED #2 PUMP ON

WATER LEVEL 7.1 FT

Dave Reddick

3:45 P.M.

Checking station

water level 3'0 feet  
downward

3:45 P.M.

CHECKING STATION

PUMPS #1, #2, #3 RUNNING

TURNED #2 OFF

WATER LEVEL - 8 FT

Dave Reddick

KCSlip4 67922

SEA436013

Tuesday, March 26, 1968

86th day - 280 days to follow

8:15 A.M.  
Checked station  
#1 & #3 pumps running  
#2 pump off  
Water level - 6.2 ft

Roy Rose

0900

Checking  
TUNIS Vodson Dorgan  
Reservoir

3:15 P.M.  
Checking stations  
#1 & #3 pumps running  
#2 pump off  
Water level? - 6.2 ft

Roy Rose

Wednesday, March 27, 1968

87th day - 279 days to follow

8:15 A.M.  
Checked station  
#1 & #3 pumps running  
#2 pump off  
C hecked still level, ok.  
Water level -- 8 ft  
Turned #2 pump on

Roy Rose

11:05 A.M.

Checking station  
water level off

E. Waggoner

3:25 P.M.  
Checking stations  
#1 - #2 & #3 pumps running  
Turned #2 pump off  
Water level - 4.0 ft

Roy

KCSlip4 67923

SEA436014

Thursday, March 28, 1968

88th day - 278 days to follow

8:20 A.M.

Checked station

#1 & #3 pumps running

#2 pump off

Water level - 6.0 ft

Ray Moore

3:15 P.M.

CHECKED STATION

#1 AND #3 PUMPS RUNNING

#2 PUMP OFF

WATER LEVEL - 6.0 FT.

Dave Roddy

Friday, March 29, 1968

89th day - 277 days to follow

8:10 A.M.

Checked station

#1 & #3 pumps running

#2 pump off

Water level - 5.9 ft

Ray Moore

3:35 P.M.

CHECKED STATION

#1 AND #3 PUMPS ~~OFF~~ Running

#2 PUMP OFF

WATER LEVEL - 6.0 FT.

Dave Roddy

KC Slip 4 67924

SEA436015

Saturday, March 30, 1968

90th day - 276 days to follow

8:00 A.M.

CHECKED STATION  
PUMPS #1 AND #3 RUNNING  
PUMP #2 OFF  
TURNING #2 PUMP ON  
WATER LEVEL - 5.4 FT.

DAVE RODDEY

1:15 P.M.

CHECKING STATION  
WATER LEVEL - 2.6 FT.  
TURNED #2 PUMP OFF

DAVE RODDEY

3:40 P.M.

CHECKED STATION  
PUMPS #1 AND #3 RUNNING  
PUMP #2 OFF

WATER LEVEL - 5.8 FT.

DAVE RODDEY

Sunday, March 31, 1968

91st day - 275 days to follow

Passion Sunday

9:00 A.M.

CHECKING STATION  
PUMPS #1 AND #3 ON, RUNNING  
PUMP #2 OFF

WATER LEVEL - 5.8 FT.

DAVE RODDEY

3:15 P.M.

CHECKING STATION  
PUMPS #1 AND #3 RUNNING  
PUMP #2 OFF

WATER LEVEL - 5.6 FT.

DAVE RODDEY

KCslip4 67925

SEA436016

Monday, April 1, 1968

92nd day - 274 days to follow

8:15 A.M.

Cheeked station

#1 & #3 pump running

#2 pump off

Water level — 5.7 ft

Rob. More

3:15 P.M.

Cheeked station

#1 & #3 pump running

#2 pump off

Water level — 5.8 ft

Rob. More

Tuesday, April 2, 1968

93rd day - 273 days to follow

8:10 A.M.

Cheeked station

#1 & #3 pump running

#2 pump off

Water level — 5.8 ft

Rob. More

9:45 A.M. Cheeked station  
water level 5.10' feet

E.W. Donagan

3:00 P.M.

Cheeked station

#1 & #3 pump running

#2 pump off

Water level — 5.10 ft

Rob. More

KCSlip4 67926

SEA436017

Wednesday, April 3, 1968

94th day - 272 days to follow

8:15 A.M.

checked station

#1 & #3 pumps running

#2 pump off

Water level - 5.8 ft.

Ray Marr

0950

Checking. Placed solid  
steel compressor drain line  
in tube leading to wet well.  
#1 + #3 running  
#2 off

MON-CON elevation 5.8'

enR.

3:30 P.M.

checked station  
PUMPS #1 and #3 RUNNING  
PUMP #2 OFF  
WATER LEVEL - 5.6'

Dave Roddy

Thursday, April 4, 1968

95th day - 271 days to follow

8:16 AM

CHECKED STATION

PUMPS #1 and #3 RUNNING

PUMP #2 OFF

WATER LEVEL - 5.6'

Dave Roddy

3:35 P.M.

CHECKED STATION  
PUMPS #1 and #3 Running  
PUMP #2 OFF  
WATER LEVEL - 5.6'

Dave Roddy

KCslip4 67927

SEA436018

Friday, April 5, 1968

96th day - 270 days to follow

8:25 A.M.

CHECKED STATION  
PUMPS #1 AND #3 RUNNING  
PUMP #2 OFF  
WATER LEVEL - 5.6'

Dave Rodley

3:25 P.M.

CHECKED STATION  
PUMPS #1 AND #3 RUNNING  
PUMP #2 OFF  
WATER LEVEL - 5.6'

Dave Rodley

Saturday, April 6, 1968

97th day - 269 days to follow

9:00 A.M.

Checked Station  
#1 & #3 pumps running  
#2 off  
Water Level 5.4'

Clarence M. Walker

3:00 PM

Checked Station  
#1 & #3 pumps running  
#2 off  
Water Level 5.6'

Clarence M. Walker

KCSlip4 67928

SEA436019

Sunday, April 7, 1968

98th day - 268 days to follow

9:10 A.M.

Palm Sunday

Checking Station

#1 & #3 pumps running

#2 pump off

Water level 5.5'

Clarence W. Miller

Monday, April 8, 1968

99th day - 267 days to follow

8:15 A.M.

Checked station

#1 & #3 pumps running

#2 pump off

Water level - 5.8 ft

Ray Moore

3:00 P.M.

Checking Station

#1 & #3 pumps running

#2 pump off

Water level 5.9'

Clarence W. Miller

3:20 P.M.

Checked station

#1 & #3 pumps running

#2 pump off

Water level - 6.0 ft

Ray Moore

KCslip4 67929

SEA436020

Tuesday, April 9, 1968

100th day - 266 days to follow

8:10 A.M.

Checked station  
#1 & #3 pumps running  
#2 pump off  
Water level - 6.0 ft

Ray Moore

3:10 P.M.

Checked station  
#1 & #3 pumps running  
#2 pump off  
Water level - 6.0 ft

Ray Moore

Wednesday, April 10, 1968

101st day - 265 days to follow

9:15 A.M.

CHECKED STATION  
PUMPS #1, #3 RUNNING  
#2 PUMP OFF  
WATER LEVEL - 6.0 FT.

Dave Rodley

3:37 P.M.

CHECKED STATION  
PUMPS #1, #3 RUNNING  
PUMP #2 OFF  
WATER LEVEL - 6.0'

Dave Rodley

KCSlip4 67930

SEA436021

Thursday, April 11, 1968

102nd day - 264 days to follow

8:30 A.M. Maundy Thursday

Checked station

#1 & #3 pumps running

#2 pump off

Water level — 6.8 ft

Ray Moore

3:00 P.M.

Checked stations

#1 & #3 pumps running

#2 pump off

Water level — 6.0 ft

Ray Moore

Friday, April 12, 1968

103rd day - 263 days to follow

8:10 A.M.

Checked pumps Good Friday station

#1 & #3 pumps running

#2 pump off

Water level — 5.8 ft

Ray Moore

2:05 P.M. Checking station  
Water level 5'9" feet.

#2 pump on auto.

Ed Dargan

3:15 P.M.

Checking station

#1, #2 & #3 pumps running

Turned #2 pump off

Water level — 5.6 ft

Ray Moore

KCslip4 67931

SEA436022

Saturday, April 13, 1968

104th day - 262 days to follow

8:20 A.M.

Cheeket station

Holy Saturday

#1 & #3 pump on

First Day of Passover

#2 pump off

Water level — 5.6 ft

Roy More

3:15 P.M.

Cheeket station

#1 & #3 pump running

#2 pump off

Water level — 6.2 ft

R. M.

Sunday, April 14, 1968

105th day - 261 days to follow

Easter Sunday

President Lincoln's Assassination

7:50 A.M.

Cheeket station

#1 & #3 pump running

#2 pump off

Water level — 5.6 ft

Roy More

3:15 P.M.

Cheeket station

#1 & #3 pump running

#2 pump off

Water level — 6.4 ft

Rainning outside

Roy More

KCSlip4 67932

SEA436023

Monday, April 15, 1968

106th day - 260 days to follow

8:50 A.M. CHECKED STATION

PUMPS #1, #3 RUNNING

PUMP #2 OFF

WATER LEVEL - 6.6'

#2 PUMP ON - PUMP WILL NOT ROTATE - MOTOR  
#3 PUMP OFF RUNS.

Dave Roddy

10:30AM.

CLEANED STICK AND HANDHEL OF RUST  
FROM #2 PUMP.

PUMPS #1, #2 RUNNING

PUMP #3 OFF

WATER LEVEL - 6.8'

RODDY - WATER

3:55 P.M. CHECKED STATION

PUMP #1, #2 RUNNING

PUMP #3 OFF

WATER LEVEL - 6.4'

Dave Roddy

Tuesday, April 16, 1968

107th day - 259 days to follow

8:30 A.M.

CHECKED STATION

PUMPS #1, #2 RUNNING

PUMP #3 OFF

TURNED PUMP #3 ON

WATER LEVEL 6.0'

Dave Roddy

10:50

Checking

Cure R

3:10 P.M.

CHECKED STATION

#1, #2 & #3 PUMPS RUNNING

TURNED #2 PUMP OFF

WATER LEVEL - 6.6 FT

Dave Moore

KCslip4 67933

SEA436024

Wednesday, April 17, 1968

108th day - 258 days to follow

8:30 A.M.

Checked station

#1 & #3 pumps running

#2 pump off

Turned #3 pump on

Water level - 6.4 ft

Roy Wiese

3:25 P.M.

Checked station

#1 & #2 pumps running

#3 off automatically

Turned #3 off manually

Water level - 5.5 ft

Roy Wiese

Thursday, April 18, 1968

109th day - 257 days to follow

8:30 A.M.

CHESED STATION

PUMPS #1 #2 RUNNING

PUMP #3 OFF

TURNED PUMP #3 ON

WATER LEVEL - 5.2'

Dave Radok

3:10 P.M.

Check - 1 station

#1 - #2 & #3 pumps running

Turned #3 pump off

Water level - 5.8 ft

Roy Wiese

KCslip4 67934

SEA436025

Friday, April 19, 1968

110th day - 256 days to follow

8:10 A.M.  
Checked station  
#1 & #2 pumps running  
Turned #3 pump off  
Water level — 6.4 ft

Dave Moore

3:30 P.M.  
Checked station  
#1 - #2 & #3 pumps running  
Turned #3 pump off  
Water level — 3.6 ft

Dave Moore

Saturday, April 20, 1968

111th day - 255 days to follow

8:00 A.M.  
Checked station  
#1 & #2 pumps running  
Turned #3 pump off  
Water level — 6.4 ft

Dave Moore

4:00 P.M.  
CHECKED STATION  
PUMPS #1, #2 RUNNING  
PUMP #3 OFF ON AUTO  
TURNED PUMP #3 OFF  
WATER LEVEL - 2.6'  
DAVE RODD

KCslip4 67935

SEA436026

Sunday, April 21, 1968

112th day - 254 days to follow

Low Sunday - First Sunday after Easter

7:25 A.M.

CHECKED STATION  
PUMPS #1, #2 RUNNING  
PUMP #3 OFF  
TURNED #3 ON  
WATER LEVEL - 4.0'

DAVE RODNEY

7:50 A.M.

WATER LEVEL 3.2'  
PUMP #3 VIBRATING BADLY - TURNED IT OFF  
LOW FLOW AT PLANT

DAVE RODNEY

3:00 P.M.

CHECKED STATION  
PUMPS #1, #2 RUNNING  
PUMP #3 OFF  
WATER LEVEL - 7'

DAVE RODNEY

Monday, April 22, 1968

113th day - 253 days to follow

8:28 A.M.

CHEKED STATION  
#1 + #2 PUMPS RUNNING  
#3 PUMPS OFF  
WATER LEVEL - 6.4 FT

RAY MORE

11:40 A.M.

CLEANED #3 PUMPS OUT & SEWAGE  
PIPE IS STILL PLUGGED BY OTHER  
WASHED DOWN STATION. WE SHALL  
UNPLUG LINE LATER IN WEEK.

RAY MORE  
ED MURRAY

3:15 P.M.

CHEKED STATION  
#1 - #2 + #3 PUMPS RUNNING  
TURNED #3 PUMPS OFF.  
WATER LEVEL - 3.8 FT

RAY MORE

KCslip4 67936

SEA436027

Tuesday, April 23, 1968

114th day - 252 days to follow

8:20 A.M.

Checked station

#1 + #2 pumps running

Turned #3 pump off

Water level — 6.8 ft

— Ray White —

3:10 P.M.

Checked station

#1 + #2 + #3 pumps running

Turned #1 pump off

Water level — 3.8 ft

Ray White

Wednesday, April 24, 1968

115th day - 251 days to follow

8:05 A.M.

Checked station

#2 + #3 pumps running

Turned #1 pump on the off again

Water level — 5.8 ft

— Ray White —

11:00 A.M.

Cleared top of #1 pump &

Turned it off.

Ray White

Bennie Martin

Everett Johnson

Ed H. Jones

1:00 P.M. - Washed all three pumps  
down to remove silt & wiped  
them clean — Ray White

3:00 P.M. - Checked station, #1 + #2  
+ #3 pumps running, left all three  
pumps on for the night.  
Water level 5 ft

Ray White

KCSlip4 67937

SEA436028

Thursday, April 25, 1968

116th day - 250 days to follow

8:15 A.M.

Checked station

#1 & #3 pumps running

#2 off automatically stand by  
light w/ little.

Water level - 3.6 ft

Reset #2 pump so lights work

Roy G. Price

8:30 A.M. Person is coming for  
for repair - # put #3 pump  
on so

T. P. Remm  
- Dayton

3:30 P.M.

Checked station

#1 & #2 & #3 pump running

Turned #3 1 pump off

Water level - 2.8 ft

Roy G. Price

Friday, April 26, 1968

117th day - 249 days to follow

8:10 A.M.

Checked station

#2 & #3 pumps running

Turned #1 pump on

Water level - 0.2 ft

Primed #1 pump to get it started

Roy G. Price

1:15 A.M.

Check Station

- Dayton

3:15 P.M.

Checked station

#1 & #3 pumps running

#3 pump off automatically

Turned #3 off manually

Water level - 3.8 ft

Roy G. Price

KCslip4 67938

SEA436029

Saturday, April 27, 1968

118th day - 248 days to follow

9:00 AM

Grant's Birthday

Checking Station  
#1 & #2 pumps running  
#3 pump off  
Water level 6.0'

Clarence W. Walker

3:10 PM

Checking Station  
#1 & #2 pumps running  
#3 pump off  
Water level 6.5'

Clarence W. Walker

Sunday, April 28, 1968

119th day - 247 days to follow

9:15 AM

Second Sunday after Easter

Checking Station  
#1 & #2 running  
#3 pump off  
Water level 5.6'

Clarence W. Walker

3:05 PM

Checking Station  
#1 & #2 pumps running  
#3 pump off  
Water level 6.4'

Clarence W. Walker

KCslip4 67939

SEA436030

Monday, April 29, 1968

120th day - 246 days to follow

8:05 A.M.

#2 PUMP RUNNING

#3 PUMP OFF

#1 PUMP OFF ON AUTO. HAD KICKED BREKHEL. RESET  
TURNED #3 PUMP ON

WATER LEVEL - 6.8'

REMOVED LARGER STICK, HAD TO LOOSES RADS FROM #1  
PUMP. STICK WOULD NOT PUMP. #1 PUMP OFF.

Dave Rooprey

9:30 A.M.

TURNED OFF ALL PUMPS

ALLOWED MATERIAL TO SETTLE 10'

TURNED ON #1 PUMP. PUMPING OK.

TURNED ON #2, #3 PUMPS.

PUMPS #1, #2, #3, ON.

Dave Rooprey

3:30 P.M.

PUMPS #1, #2, #3 RUNNING

TURNED #3 PUMP OFF

WATER LEVEL - 4.2'

Dave Rooprey

Tuesday, April 30, 1968

121st day - 245 days to follow

Last Day for employers to file quarterly Social Security Tax Return  
and Wage Report, covering three previous calendar months

8:15 A.M.

Checked station

#1 & #3 pumps running

Turned #3 pump on  
Water level - 5.6 ft

Pay 42000

3:15 P.M.

Checked station

#1, #2 & #3 pumps running

Turned #3 pump off

Water level - 3.2 ft

Pay 42000

KCslip4 67940

SEA436031

Wednesday, May 1, 1968

122nd day - 244 days to follow

9:55 A.M.

CHECKED STATION  
PUMPS #1, #2 RUNNING  
PUMP #3 OFF  
WATER LEVEL - 3.8'  
PUMP #3 ON.

Dave Rooney

9:30 A.M.

Check. g. station #3 noisy  
rags or debris? will have it  
cleaned out

Ed Longen

3:00 P.M.

CHECKED STATION  
PUMPS #1, #2 RUNNING  
PUMP #3 OFF. SUCING AIR THRO SEAL CAVITY  
VENT PLUG.

WATER LEVEL - 4.0'

Dave Rooney

Thursday, May 2, 1968

123rd day - 243 days to follow

8:15 A.M.

Checked station  
#1 & #2 pumps running  
#3 pump off  
Water level - 4.0 ft.

- Ray Moore -

3:25 P.M.

Checked station  
#1 - #2 & #3 pumps running  
#3 pump off  
Water level - 3.8 ft

Ray Moore

KCslip4 67941

SEA436032

Friday, May 3, 1968

124th day - 242 days to follow

8:15 A.M.

Checked station

#1 & #2 pumps running

Turned #3 pump on

Water level — 4.6 ft

Roy Moore

3:25 P.M.

Checked station

#1 & #2 & #3 pumps running

Turned #3 pump off

Water level — 2.8 ft

Roy Moore

Saturday, May 4, 1968

125th day - 241 days to follow

8:15 A.M.

Checked station.

#1 pump running

#2 pump off automatically

#3 pump off

Turned #2 pump on, but st. off. 55  
Water level — 2.4 ft

Roy Moore

3:20 P.M.

Checked station

#1 - #2 + #3 pumps running

Turned #3 pump off

Water level — 3.4 ft

Roy Moore

KCslip4 67942

SEA436033

Sunday, May 5, 1968

126th day - 240 days to follow

Third Sunday after Easter

8:00 A.M.  
checked station  
#1 + #2 pumps running  
Turned #3 pump on.  
Water level — 4.1 ft

Ray Moore

3:00 P.M.  
checked station  
#1 - #2 + #3 pumps running  
Turned #3 off  
Water level — 4.0 ft

Ray Moore

Monday, May 6, 1968

127th day - 239 days to follow

9:00 A.M.  
CHECKED STATION  
PUMPS #1, #2 Running  
PUMP #3 OFF  
WATER LEVEL 6 FT.  
PUMP #3 ON. STILL SUCKING AIR INTO SEAL CAVITY  
VENT PLUG. TURNED #3 PUMP OFF, TAGGED IT OUT.

DAVE RODDY

3:37 P.M.  
PUMPS #1, #2 RUNNING  
PUMP #3 OFF  
WATER LEVEL - 6.6'

DAVE RODDY

KCslip4 67943

SEA436034

Tuesday, May 7, 1968

128th day - 238 days to follow

8:40 A.M.

CHECKED STATION

PUMPS #1, #2 RUNNING

#3 OFF (SEE MONDAY MORN)

WATER LEVEL - 5.6'

DAVE RODDEY

Maint. Edwards & Clyde checked  
#3 pump to report to Maint. Syp. W.R.

3:35 P.M.

CHECKED STATION

PUMPS #1, #2 RUNNING

#3 OFF

WATER LEVEL - 6.6'

DAVE RODDEY

Wednesday, May 8, 1968

129th day - 237 days to follow

8:10 A.M.

CHECKED STATION

#1 & #2 PUMPS RUNNING

#3 PUMP TAGGED OUT

WATER LEVEL - 5.4 FT

Ray Moore

3:15 P.M.

CHECKED STATION

#1 & #2 PUMPS RUNNING

#3 PUMP TAGGED OUT

WATER LEVEL - 6.4 FT

Ray Moore

KCslip4 67944

SEA436035

Thursday, May 9, 1968

130th day - 236 days to follow

8:20 A.M.

CHECKED STATION  
PUMPS #1, #2 RUNNING  
PUMP #3 TAGGED OUT.  
WATER LEVEL - 6.2'  
DAVE RODDEY

Friday, May 10, 1968

131st day - 235 days to follow

8:26 A.M.

CHECKED STATION  
PUMPS #1, #2, RUNNING  
PUMP #3 TAGGED OUT  
RETURNED PUMP #3 TO SERVICE - SPILL SUCKING AIR  
WATER LEVEL - 5.0'

DAVE RODDEY

3:00 P.M.

CHECKED STATION  
PUMPS #1, #2, #3, Running  
TURNED PUMP #3 OFF  
WATER LEVEL - 3.4'

DAVE RODDEY

2:00 P.M.

CHECKED STATION  
PUMPS #1, #2, RUNNING  
PUMP #3 TAGGED OUT.  
WATER LEVEL - 6.2'

DAVE RODDEY

KCSlip4 67945

SEA436036

Saturday, May 11, 1968

132nd day - 234 days to follow

8:45 A.M.

CHECKED STATION  
PUMPS #1, #2 RUNNING  
PUMP #3, OFF  
TURNED PUMPS ON. - NOW OFF ON AUTO.  
WATER LEVEL - 3.6'

DAVE RODDIE

3:45 P.M.

CHECKED STATION  
PUMPS 1, 2, 3 RUNNING  
TURNED PUMP #3 OFF  
WATER LEVEL - 3.0'

DAVE RODDIE

Sunday, May 12, 1968

133rd day - 233 days to follow

Fourth Sunday after Easter

Mother's Day

8:10 A.M.

CHECKED STATION  
PUMPS #1, #2 RUNNING  
PUMP #3 OFF  
TURNED PUMP #3 ON  
WATER LEVEL - 3.8'

DAVE RODDIE

3:30 P.M.

CHECKED STATION  
PUMPS #1, #2 RUNNING  
PUMP #3 OFF ON AUTO  
TURNED PUMP #3 OFF  
WATER LEVEL 3.6'

DAVE RODDIE

KCslip4 67946

SEA436037

Monday, May 13, 1968

134th day - 232 days to follow

8:00 A.M.  
Checking station  
water level 3.5 feet  
#1 & #2 running  
#3 not in service for  
the day.  
Checked oil level on all  
pumps (O.T.)

E.W. Morgan

3:40 PM  
Checked Station  
#1 & #2 pumps running  
#3 pump not running.  
Water level 3.2'  
#3 pump turned off

Claudence H. Walker

10:30 AM R.H. Brown and Abbie Gold  
checked #3 sewage pump E.W. Morgan

Tuesday, May 14, 1968

135th day - 231 days to follow

8:20 AM. Checking station  
water level 3.3 feet.  
Checked oil level.  
#1, #2 & #3 are automatic

E.W. Morgan

3:15 PM. Checking

water level 3.5 feet.  
Resumed #3 from Service  
#5 off on auto.

E.W. Morgan

KCSlip4 67947

SEA436038

Wednesday, May 15, 1968

136th day - 230 days to follow

8:20 A.M.  
Checked station  
#1 <sup>#2</sup> pump running,  
#3 pump off  
Turned #3 pump on auto  
Water level — 3.4 ft

Roy Moore

3:10 P.M.  
Checked station  
#1 & #2 pumps running  
#3 pump on auto  
Turned #3 pump off  
Water level — 3.4 ft

Roy Moore

Thursday, May 16, 1968

137th day - 229 days to follow

8:20 A.M.  
CHECKED STATION  
PUMPS #1, #2 RUNNING  
PUMP #3 OFF  
TURNED PUMP #3 ON - OFF ON AUTO  
WATER LEVEL - 3.0 FT

DAVE RODNEY

3:40 P.M. Checking station  
water level 3 1/4 " feet  
#1 & #3 on auto.  
shut #3 off for check.

ECC Langau

KCSlip4 67948

SEA436039

Friday, May 17, 1968

138th day - 228 days to follow

8:30 A.M.

CHECKED STATION

WATER LEVEL - 4.0'

PUMPS #1, #2 Running ON AUTO

PUMP #3 OFF

TURNED #3 PUMP ON AUTO - RUNNING.

DAVE RODNEY

Saturday, May 18, 1968

139th day - 227 days to follow

Armed Forces Day

9:00 AM

checked Station

#1 & #2 pumps running

#3 pump off

Water level 3.8'

Clarence W. Walker

8:30 P.M.

CHECKED STATION

WATER LEVEL - 2.8'

PUMPS #1, #2 Running ON AUTO

PUMP #3 OFF ON AUTO

TURNED #3 PUMP OFF FOR NIGHT

DAVE RODNEY

3:00 PM

checked Station

#1 & #2 pumps running

#3 pump off

Water level 4.4'

Clarence W. Walker

KCslip4 67949

SEA436040

Sunday, May 19, 1968

140th day - 226 days to follow

7:00 A.M.

Checked Station

#1 & #2 pumps running

#1 pump very hot - water

Near boiling. Clean rags  
out okay now.

#3 pump off

Water level 8.2'

Clarence W. Walker

3:00 P.M.

Checked Station

#1 & #2 pumps running

#3 pump off

Water level 4.8'

Clarence W. Walker

Monday, May 20, 1968

141st day - 225 days to follow

8:30 AM

Checked Station

#1 & #2 pumps running

Turned #3 pump on auto  
Water Level 5.0'

Clarence W. Walker

10:45 AM

Remained #3 Pump - Took to  
West Point for Repair  
Lyle & Clyde

3:25 PM

Checked Station

#1 & #2 pumps running

Water level 6.4'

Clarence W. Walker

KCSlip4 67950

SEA436041

Tuesday, May 21, 1968

142nd day - 224 days to follow

8:30 A.M.  
CHECKED STATION  
PUMPS #1, #2 Running  
PUMP #3 UNDER RESERVOIR  
WATER LEVEL - 5.2'  
DAVE RODDEY

10:45 A.M. Checking station  
Water level 5.5" feet

2:30 P.M. 600 Dongan  
Replaced #3 Pump & Drained  
Seal Cavity in #1 & 2  
Lyle & Clyde

3:15 P.M.  
CHECKED STATION  
REMOVED SEAL CAVITY AND BEARING CAVITY, #3 PUMP  
PUMPS #1, #2 Running  
PUMP #3 OFF  
WATER LEVEL - 6.2'  
DAVE RODDEY

Wednesday, May 22, 1968

143rd day - 223 days to follow

8:50 A.M.  
CHECKED STATION  
PUMPS #1, #2 RUNNING  
PUMP #3 OFF  
TURNED PUMP #3 ON - RETURNED TO SERVICE  
WATER LEVEL - 4.0'  
Dave Roddey

3:45 P.M.  
CHECKED STATION  
PUMPS #1, #2 RUNNING  
PUMP #3 OFF ON AUTO. TURNED IT OFF  
WATER LEVEL - 3.8'  
DAVE RODDEY

KC Slip 4 67951

SEA436042

Thursday, May 23, 1968

144th day - 222 days to follow

Ascension Day

3:45 A.M.

CHECKED STATION

PUMPS #1, #2 RUNNING

PUMP #3 OFF

TURNED #3 PUMP ON. - OFF ON AUTO

WATER LEVEL - 3.2'

DAVE RODDEY

3:30 P.M.

CHECKED STATION

PUMPS #1, #2, #3 RUNNING

TURNED PUMP #3 OFF

WATER LEVEL - 2.4'

DAVE RODDEY

Friday, May 24, 1968

145th day - 221 days to follow

8:35 A.M.

CHECKED STATION

PUMPS #1, #2 RUNNING

PUMP #3 OFF - TURNED IT ON - TURNED IT OFF

PUMP #3 LEAKING WATER FROM SEAL CAVITY, HAS

LEAKED LARGE PUFFS OF OIL ALSO. BEARING CAVITY O.K.

WATER LEVEL - 5.2'

DAVE RODDEY

2:30 P.M.

CHECKED STATION

PUMPS #1, #2 Running

PUMP #3 OUT OF SERVICE FOR REPAIRS BY Maint.

WATER LEVEL - 6.8'

DAVE RODDEY

KCSlip4 67952

SEA436043

Saturday, May 25, 1968

146th day - 220 days to follow

8:20 A.M.

CHECKED STATION

PUMPS #1, #2 RUNNING

PUMP #3 OFF

WATER LEVEL - 6.8'

DAVE RODDEY

Sunday, May 26, 1968

147th day - 219 days to follow

8:30 A.M.

CHECKED STATION

PUMPS #1, #2 RUNNING

PUMP #3 OFF

WATER LEVEL - 5'

DAVE RODDEY

3:30 P.M.

CHECKED STATION

PUMPS #1, #2 Running

PUMP #3 TAGGED OUT

WATER LEVEL - 6.0'

DAVE RODDEY

3:05 P.M.

CHECKED STATION

PUMPS #1, #2 Running

PUMP #3 OFF

WATER LEVEL - 6.6'

DAVE RODDEY

KCslip4 67953

SEA436044

Monday, May 27, 1968

148th day - 218 days to follow

8:15 A.M.

Checked station Montezuma  
has engine out of #3 pump  
apparently trying to locate a  
seal for same.

#1 & #3 on line  
water level 6.3" feet.

Emeloyan

3:30 P.M.

Checked station  
#1 & #2 pumps running  
Water 6.4"

Clarence W. Walker

Tuesday, May 28, 1968

149th day - 217 days to follow

8:15 A.M.

CHECKED STATION  
PUMPS #1, #2 RUNNING  
PUMP #3 TAGGED OUT  
WATER LEVEL - 4.2'

DAVE RODDEY

3:30 P.M.

#3 pump out of service due  
to work by maintenance.

#1 & #2 running  
water level 5.9" feet

Emeloyan

KCslip4 67954

SEA436045

Wednesday, May 29, 1968

150th day - 216 days to follow

8:30 A.M.  
PUMPS #1, #2 Running  
PUMP #3 OFF  
WATER LEVEL - 5.0'  
DAVE RODDY

Thursday, May 30, 1968

151st day - 215 days to follow

0800

Memorial Day

Pump #1 running  
Pumps #2 + #3 out of service  
Water level 8.6'

Clarence W. Walker

1145

CHECK #2 Pump  
TOWNS

1500

Pump #1 running  
Pumps #2 + #3 out of service  
Water level 8.4'

Florence W. Walker

3:40 P.M.  
CHECKED STATION  
PUMP #1 RUNNING  
PUMP #2 OFF ON AUTO (#3 pump will not  
run E.W.A.)  
PUMP #3 OFF  
WATER LEVEL - 8.6'  
DAVE RODDY

KC Slip 4 67955

SEA436046

Friday, May 31, 1968

152nd day - 214 days to follow

0800

REPLACE UNDER RATED  
OVERLOADS ON #1, 2, & 3  
PUMP CONTROL UNITS

Baylor & Jones

130 PM Cleaning station

water level 6'0" feet

full range

1515

checked Station  
Pumps #1 & #2 running  
Pump #3 out of service  
Water level 6.2'

Clarence W. Walker

Saturday, June 1, 1968

153rd day - 213 days to follow

0830

checked Station  
Pumps #1 & #2 running  
Pump #3 out of service  
Water level 6.2'

Clarence W. Walker

1500

checked Station  
Pumps #1 & #2 running  
Pump #3 out of service  
Water level 6.2'

Clarence W. Walker

KCslip4 67956

SEA436047

Sunday, June 2, 1968

154th day - 212 days to follow

Whitsunday - Pentecost (Christian)

First Day of Pentecost (Jewish)

8:00 AM. Checked station  
Water level 6.6" feet

\*#1 pump running  
\*#2 put #3 back in service  
\*#3 off out of service due to  
maneuver working or stone  
(no seal)

Ed Langard

1500 PM

Checked Station  
Pumps #1 & #2 running  
Pump #3 out of service  
Water level 6.2'

Clarence W. Mallon

Monday, June 3, 1968

155th day - 211 days to follow

8:35 A.M.

CHECKED STATION

PUMP #1, #2 RUNNING

PUMP #3 TAGGED OUT BY MAINT.  
WATER LEVEL - 6.0'

DAVE RODDY

8:35 P.M.

CHECKED STATION

PUMPS #1, #2 Running

PUMP #3 OFF

WATER LEVEL - 6.0'

DAVE RODDY

KC Slip 4 67957

SEA436048

Tuesday, June 4, 1968

156th day - 210 days to follow

8:25 A.M.

CHECKED STATION

PUMPS #1, #2 Running

PUMP #3 OFF FOR REPAIRS

WATER LEVEL - 6.0'

DAVE RODDY

3:25 PM

CHECKED STATION

PUMPS #1, #2 Running

Pump #3 OFF

WATER LEVEL - 6.0'

DAVE RODDY

Wednesday, June 5, 1968

157th day - 209 days to follow

8:20 A.M.

CHECKED STATION

PUMP #1, #2 Running

PUMP #3 OFF

WATER LEVEL - 6.0'

100PM DAVE RODDY  
Removed seal from #3 pump  
for sample to Reorder

Lyle & Lee

3 PM

Replaced Seal #3 pump  
Pump O.K., Lyle & Lee

3:30 P.M.

CHECKED STATION

PUMPS #1, #2 Running

PUMP #3 OFF

WATER LEVEL 6.0'

DAVE RODDY

KC Slip 4 67958

SEA436049

Thursday, June 6, 1968

158th day - 208 days to follow

8:35 A.M.

CHECKED STATION  
PUMPS #1, #2 RUNNING  
PUMP #3 OFF  
WATER LEVEL - 42'

PUT 30WT OIL IN SEAL CAVITY, #3 PUMP  
ADDED 30WT OIL TO SEAL CAVITIES - #1, #2 PUMPS.  
RETURNED #3 PUMP TO SERVICE  
WIPED GREASE MARKS FROM PUMPS.

DAVE RODDEY

Friday, June 7, 1968

159th day - 207 days to follow

8:35 A.M.

CHECKED STATION  
PUMPS #1, #2 RUNNING  
PUMP #3 OFF - TURNED IT ON AUTO  
WATER LEVEL - 4'

DAVE RODDEY

3:30 P.M.

CHECKED STATION  
PUMPS #1, #2, #3, Running

WATER LEVEL - 3.8'

TURNED PUMP #3 OFF FOR N.T.E.

DAVE RODDEY

3:45 P.M. Checking station  
water level 3' 4" feet  
# off for the night  
# 2 on auto.

E. Sargent

KC Slip 4 67959

SEA436050

Saturday, June 8, 1968

160th day - 206 days to follow

7:20 A.M.

CHECKED STATION

PUMPS #1, #2 Running

PUMP #3 OFF - TURNED IT ON - MADE LAD Rotating NOISE  
WATER LEVEL - 3.2'

DAVE RODDEY

Sunday, June 9, 1968

161st day - 205 days to follow

Trinity Sunday

8:50 A.M. CHECKED STATION

PUMPS #1, #2 RUNNING

PUMP #3 OFF

WATER LEVEL - 4.8'

DAVE RODDEY

3:40 P.M.

CHECKED STATION

PUMPS #1, #2 Running

PUMP #3 OFF

WATER LEVEL - 7.1'

DAVE RODDEY

3:40 P.M.

CHECKED STATION

PUMPS #1, #2 Running

PUMP #3 OFF

WATER LEVEL - 6.6'

DAVE RODDEY

KCslip4 67960

SEA436051

Monday, June 10, 1968

162nd day - 204 days to follow

8:00 AM  
Checking station

#1 & #2 running  
Started #3 and found it noisy  
will leave off until maintenance  
checks same.  
Checked oil level on all pumps  
water level 5' feet

C.W. Morgan

Maintenance checked #3 pump and  
removed 2x4" and rags

3:30 PM

Checking station  
#1 & #2 pumps running  
#3 pump off  
Water level 6.4'

Elmer W. Walker

Tuesday, June 11, 1968

163rd day - 203 days to follow

8:00 AM. Checking station  
found #2 pump relay backed out  
reset some will check later  
#1 pump running (auto)  
#2 pump now running again (auto)  
#3 pump off  
water level 4' feet.

C.W. Morgan

11:20 Checked full load current on pumps

#1 - 22.0 amperes

#2 - 22.75 amperes

Baylor

3:20 PM

Checked Station  
#1 & #2 pumps running  
#3 pump off  
Water level 6.8'

Elmer W. Walker

KCslip4 67961

SEA436052

Wednesday, June 12, 1968

164th day - 202 days to follow

8:30 A.M.

CHECKED STATION

PUMPS #1, #2 RUNNING ON AUTO

PUMP #3 OFF TO KEEP WATER LEVEL ABOVE PUMP  
INTAKE LINES SO THAT DEBRIS WILL NOT GET INTO  
PUMPS

WATER LEVEL - 5.8'

DAVE RODDY

1:30 Checked full load - current  
on #1 pump 23 amperes  
#2 " 24 amperes  
Voltage to motors 470

Baylor/Jones

3:30 P.M.

Checked station

#1 & #2 pumps running

#3 pump off

Water level - 6.8'

Clarence W. Walker

Thursday, June 13, 1968

165th day - 201 days to follow

Corpus Christi

8:15 A.M.

CHECKED STATION

PUMPS #1, #2 RUNNING

PUMP #3 OFF

WATER LEVEL - 5.8'

DAVE RODDY

3:30 P.M.

CHECKED STATION

PUMPS #1, #2 RUNNING

PUMP #3 OFF

WATER LEVEL - 6.6'

DAVE RODDY

KCslip4 67962

SEA436053

Friday, June 14, 1968

166th day - 200 days to follow

9:35 A.M.

Flag Day

CHECKED STATION

PUMPS #1, #2 RUNNING

PUMP #3 OFF

WATER LEVEL - 4.8'

DAVE RODDIEY

3:40 P.M.

CHECKED STATION

PUMPS #1, #2 RUNNING

PUMP #3 OFF

WATER LEVEL - 6.6'

DAVE RODDIEY

Saturday, June 15, 1968

167th day - 199 days to follow

9:00 A.M.

checked Station

#1 & #2 pumps running

#3 pump off

Water level 5.2'

Clarence W. Walker

3:00 PM

checked Station

#1 & #2 pumps running

#3 pump off

Water level 6.4'

Clarence W. Walker

KCslip4 67963

SEA436054

Sunday, June 16, 1968

168th day - 198 days to follow

Father's Day

8:30 A.M.

Checked Station

#1 & #2 pumps running  
#3 pump off

Water level 5.1'

Clarence M. Walker

3:00 P.M.

Checked Station

#1 & #2 pumps running  
#3 pump off

Water level 6.2'

Clarence M. Walker

Monday, June 17, 1968

169th day - 197 days to follow

8:30 A.M.

CHECKED STATION

PUMPS #1, #2 RUNNING

PUMP #3 OFF

WATER LEVEL - 3.8'

DAVE RODDIE

3:30 P.M.

CHECKED STATION

PUMPS #1, #2 RUNNING

PUMP #3 OFF

WATER LEVEL - 5.6'

DAVE RODDIE

KCslip4 67964

SEA436055

Tuesday, June 18, 1968

170th day - 196 days to follow

8:25 A.M.

CHECKED STATION

PUMPS #1, #2 Running

PUMP #3, OFF

WATER LEVEL - 3.2'

DAVE RODDIEY

3:30 P.M.

CHECKED STATION

PUMPS #1, #2 Running

PUMP #3 OFF

WATER LEVEL - 5.6'

DAVE RODDIEY

Wednesday, June 19, 1968

171st day - 195 days to follow

9:20 A.M.

CHECKED STATION

PUMPS #1, #2 Running

PUMP #3 OFF

WATER LEVEL - 7.2'

DAVE RODDIEY AND Frank HARDING

3:45 P.M.

Checked Station

Pumps 1 & 2 Running

Pump #3 off

WATER LEVEL - 6.6'

Frank HARDING & DAVE RODDIEY

KCslip4 67965

SEA436056

Thursday, June 20, 1968

172nd day - 194 days to follow

8:50 A.M.

Checked Station

Pumps #1 & #2 Running

Pump #3 off

WATER LEVEL 4.0'

Frank Harding & Dave Rooney

3:40 P.M.

Checked Station

Pumps #1 & #2 running

Pump #3 off

WATER LEVEL 6.4'

Frank Harding & Dave Rooney

Friday, June 21, 1968

173rd day - 193 days to follow

Feast of the Sacred Heart

8:50 A.M.

Checked Station

Pumps #1 & #2 Running

Pump #3 off

WATER LEVEL 4.0'

Frank Harding &

CHANGED LEAD PUMPS

PUMPS #2, #3 Running

PUMP #1 OFF

Dave Rooney & Frank Harding

3:30 P.M. Checking station

#1 & #2 pumps on auto,

#3 off line for the week end  
water level 4' 3" feet

Evelyn Longman

KCSlip4 67966

SEA436057

Saturday, June 22, 1968

174th day - 192 days to follow

8:00 P.M.

Checked station

# found #1 pump full of rocks  
and sticks. removed some

water level 9.2'

Checked oil in motor.  
# 2 & #3 running auto.

Tekelorgan

2:00 P.M.

Checked station

# 2 & #3 on auto

water level 6 feet.

Tekelorgan

Sunday, June 23, 1968

175th day - 191 days to follow

8:00 A.M.

Checked station

water level 4' feet

#2 on auto only

checked oil in all motor

Tekelorgan

3:45 P.M. Checked station

#1 & #3 pumps are clogged  
up - will remove some  
tomorrow

#2 running on auto.

water level 4.5' feet.

Tekelorgan

KCslip4 67967

SEA436058

Monday, June 24, 1968

176th day - 190 days to follow

5:30 A.M.

Checked station

#2 pump running

#1 & #3 pumps off

removed bags from #3 pump

Water level 8.8'

#1 & #2 pumps on auto running

#3 pump has a noise - off

Clarence W. Walker

10:30 AM

CLEANED STATION

Alan M. Ackerson

3:30 P.M.

CHECKED STATION

Pumps #1 & #2 running

Pump #3 off

WATER LEVEL 7.7'

FRANK HARDING

{ 10:30

{ Edwards - Chester & Clyde here checked

{ #3 pump opened some twice found nothing

{ Pumps still noisy, Edwards said they

{ would check some later & remove from service

{ & tag out. Ed Morgan

Tuesday, June 25, 1968

177th day - 189 days to follow

9:10 A.M.

CHECKED STATION

Pumps #1 & #2 running

Pump #3 off

WATER LEVEL 4.7'

FRANK HARDING

3:40 P.M.

CHECKED STATION

Pumps #1 & #2 running

Pump #3 off

WATER LEVEL 6-10'

FRANK HARDING

KCSlip4 67968

SEA436059

Wednesday, June 26, 1968

178th day - 188 days to follow

8:40 A.M.

Checked Station

Pumps #1 & #2 Running

Pump #3 off & tagged out

WATER LEVEL 4-4'

FRANK HARDING

100 P.M.

#3 pump still tagged out  
Water level 6 1/2" full

Cullenger

3:40 P.M.

Checked Station

Pumps #1 & #2 Running

Pump #3 off

WATER LEVEL 6-9'

FRANK HARDING

Thursday, June 27, 1968

179th day - 187 days to follow

8:30 A.M.

Checked Station

Pumps #1 & #2 Running

Pump #3 off

WATER LEVEL 7-0'

FRANK HARDING

3:35 P.M.

Checked Station

Pumps #1 & #2 Running

Pump #3 off

WATER LEVEL 7-4'

FRANK HARDING

KCslip4 67969

SEA436060

Friday, June 28, 1968

180th day - 186 days to follow

8:50 A.M.

Checked Station

#3 Pump Tagged out still

Turned Pump #1 & #2 off because  
of overheating - cleaned out rings &  
restarted.

Pumps #1 & #2 running

Water Level 10-0'

Frank Harding & Walker

3:45 P.M.

Checked Station

Pumps #1 & #2 running

Pump #3 off

Water Level 7-2'

Frank Harding

Saturday, June 29, 1968

181st day - 185 days to follow

9:00 AM

Checked Station

#3 pump off

#1 & #2 pumps running

Water level 4.8'

Clarence W. Walker

3:00 PM

Check Station

#3 pump off

#1 & #2 pumps running

Water level 6.8'

Clarence W. Walker

KC Slip 4 67970

SEA436061

Sunday, June 30, 1968

182nd day - 184 days to follow

7:15 AM

Checked Station  
Pumps #1 & #2 running  
Pump #3 off  
Water level 4.2'

Glarence W. Walker

3:20 PM

Checked Station  
Pumps #1 & #2 running  
Pump #3 off  
Water level 6.8'

Glarence W. Walker

Monday, July 1, 1968

183rd day - 183 days to follow

8:35 AM

Checked Station  
Pumps #1 & #2 running  
Pump #3 off  
Water level 5.3'

Frank Harding

3:25 P.M.

Checked Station  
Pumps #1 & #2 running  
Pump #3 off  
Water level 7.3'

Frank Harding

KC Slip 4 67971

SEA436062

Tuesday, July 2, 1968

184th day - 182 days to follow

8:30 A.M.

Checked STATION

Pumps #1 & #2 RUNNING

Pump #3 off

WATER LEVEL 5-4'

FRANK HARDING

8:45 Checking station  
water level 5'6" full  
#1 & #2 on auto -  
#3 still tagged out  
because of noise

SWallowtail

3:40 P.M.

Checked STATION

Pumps #1 & #2 running

Pump #3 off

WATER LEVEL 7-1'

FRANK HARDING

Wednesday, July 3, 1968

185th day - 181 days to follow

7:55 A.M.

Checked STATION

Pumps #1 & #2 off Running

Pump #3 still Tagged off

WATER LEVEL 5-4'

FRANK HARDING

3:40 P.M.

Checked STATION

Pumps #1 & #2 running

Pump #3 off

WATER LEVEL 7-0'

FRANK HARDING

KCslip4 67972

SEA436063

Thursday, July 4, 1968

186th day - 180 days to follow

5:45 AM

Independence Day

Checked Station  
Pumps #1 & #2 running  
Pump #3 off  
Water level 5.2'

Clarence W. Walker

3:00 PM

Checked Station  
Pumps #1 & #2 running  
Pump #3 off  
Water level 5.8'

Clarence W. Walker

Friday, July 5, 1968

187th day - 179 days to follow

8:15 AM.

Checked Station  
Pumps #1 & #2 running  
Pump #3 still tagged off  
Shut off #1 pump because of  
OVER HEATING.

WATER LEVEL 8-0'

Shut off pump #2 because of  
OVER HEATING - CLEANED OUT RIGGS  
& TURNED BACK. (OK)

WATER LEVEL 6-0'

FRANK HARDING

10:30 AM

Shut #1 pump off. WATER LEVEL 2-0'

CL. W. W.

3:40 PM.

Checked STATION  
Pump #1 turned off because of work  
on line.  
Pump #2 on but not running due to  
LOW WATER LEVEL.  
Pump #3 still tagged off  
WATER LEVEL 2-8'.  
FRANK HARDING

KCSlip4 67973

SEA436064

Saturday, July 6, 1968

188th day - 178 days to follow

8:05 A.M.

Checked Station

Turned on Pump #1

Pump #1 & #2 running

Pump #3 still tagged off

Water Level 8-8'

Frank Harding

3:40 P.M.

Checked Station

Pumps #1 & #2 running

Pump #3 off

Water Level 6-9'

Frank Harding

Sunday, July 7, 1968

189th day - 177 days to follow

8:15 A.M.

Checked Station

Pumps #1 & #2 running

Pump #3 still tagged off

Water Level 5-3'

Frank Harding

3:30 P.M.

Checked Station

Pumps #1 & #2 running

Pump #3 tagged off

Water Level 5-8'

Frank Harding

KCslip4 67974

SEA436065

Monday, July 8, 1968

190th day - 176 days to follow

8:30 A.M.

Checking station  
#1 & #2 pump running  
#3 tagged out - Maintenance is  
aware of this  
checked oil  
water level 6' 2"

Ed Dargan

3:30 P.M.

Checked Station  
#1 & #2 pump running  
#1 pump hot - removed  
rags okay now.  
#3 pump off  
Water 8' 0"

Glarence W. Walker

Tuesday, July 9, 1968

191st day - 175 days to follow

9:00 A.M.

PUMPS #1, #2 RUNNING  
PUMP #3 TAGGED OUT.  
WATER LEVEL - 5.6'  
CHECKED OIL

DAVE RODDY

3:30 Checking station #3 pump

Ed Dargan  
Tom Rice.

3:30 P.M.

CHECKED STATION  
PUMPS #1, #2, Running  
PUMP #3 OFF  
WATER LEVEL - 7.2'

DAVE RODDY

KC Slip 4 67975

SEA436066

Wednesday, July 10, 1968

192nd day - 174 days to follow

8:05 A.M.

Checked Station

Pumps #1 & #2 running  
Pump #3 still tagged out  
WATER LEVEL 5-0'

Frank Harding

3:40 P.M.

Checked Station

Pumps #1 & #2 running  
Pump #3 tagged out & taken apart  
WATER LEVEL 7-2'

Frank Harding

Thursday, July 11, 1968

193rd day - 173 days to follow

8:00 A.M.

Checked Station

Pumps #1 & #2 running  
Pump #3 tagged off, & under repair

WATER LEVEL 5-8'

Frank Harding

10:00 AM

Replaced #3 Pump Still  
Maisy

Lyle & Dennis

11:30 AM

Dennis Brown and Wendy checked  
#3 pump

El Doran

11:5 AM L. Rummel and El Doran  
checked #3 pump El Doran  
W.Wold & B Wagner checked  
#3 pump.

3:50 P.M. - Checked Station

Pump #1 & #2 running

Pump #3 off

WATER LEVEL 8-0'

Frank Harding

KCslip4 67976

SEA436067

Friday, July 12, 1968

194th day - 172 days to follow

8:20 A.M.

Checked Station

Pumps #1 & #2 running

Pump #3 off

Water Level 8.0'

Frank Haroing

09:00

Maintenance Added .030 Shims

To Impeller of #3 pump.  
Early.

11:00 A.M. Installed shims  
in pump, and air bypass  
pipe on pump #3  
Wendy + See

Saturday, July 13, 1968

195th day - 171 days to follow

8:00 A.M.

CHECKED STATION

PUMPS #2, #3 RUNNING

PUMP #1 OFF

WATER LEVEL - 6.0'

Dave Roppey

3:45 P.M.

CHECKED STATION

PUMP #3 RUNNING

TURNED #2 PUMP OFF OVERHEATING

#1 PUMP WOULD NOT PUMP - CHECKED PRIME - TURNED PUMP  
OFF.

WATER LEVEL - 9.6'

Dave Roppey

KCslip4 67977

SEA436068

Sunday, July 14, 1968

196th day - 170 days to follow

10:15 AM.

CHECKED STATION

PUMP #3 RUNNING

REMOVED 1/2 BUCKET RAGS FROM #2 PUMP

CHECKED #1 PUMP FOR RAGS - CLEAN

COULD NOT GET PUMPS #1, #2 TO PUMP. SUCTION LINES MUST BE PLUGGED.

WATER LEVEL - 9' 4"

DAVE RODDEY

3:40 PM.

PUMP #3 RUNNING

PUMPS #1, #2, off - still will not pump.

WATER LEVEL - 9' 0'

DAVE RODDEY

9:15 Checked pumps - Removed rags from #1, #2 pumps. Pumped for awhile then plugged up again. Left both off #3 pump - water level 8' 5".

Leave long on

Monday, July 15, 1968

197th day - 169 days to follow

8:00 AM Checking station

Open suction line both on #1 & #3 and blow out - both plugged - got #1 open and back in service - #3 still plugged up. Water level was 10.5 at 8:00 AM. 9:30 it is 6.7 feet

Ed Dorgan  
Frank Harding  
Tom Russell

1:15 PM Checking station

Pumps #1 & #3 running - Pump #2, still not going - Water level 7' 8"

Frank Harding

1:30 PM. Checking station

#1 & #3 pumping  
#2 still not pumping

Dorgan &  
Russell

3:35 Checking station

#1 & #3 pumping - #2 off  
Water level 7' 8"

Frank Harding

KCSlip4 67978

SEA436069

Tuesday, July 16, 1968

198th day - 168 days to follow

7:55 Checking Station

Shut off pump #1 because of overheating  
pump #2 off - pump #3 running  
Water level 5-9'

Frank Harding

9:25

Water level 7-2'

CLEANED RAGS FROM #1 PUMP - #1 running  
Frank Harding

1:03 P.M. Checking

#1 & #3 passing the sum.  
To be plugged at suction side  
will not go Maintenance.

Call Dragon

3:45 P.M. Checking STATION

Pumps #1 & #3 running  
Pump #2 off  
Water level 7-8'

Frank Harding

Wednesday, July 17, 1968

199th day - 167 days to follow

8:05 A.M. Checking Station

Pumps #1, #2 & #3 running  
Pump #2 off  
Water level 3-7'

Frank Harding

Seal IN Seal cavity is leaking  
on #2 pump

EWR.

Removed wires of #2  
to be reworked

Wendy

1:05 P.M.

WATER LEVEL - 4-4 - SHUT OFF #3 PUMP

#3 keeps losing pumping action Roddy - Frank & Harding  
lifted turned on.

3:28 P.M.

PUMP #1 RUNNING  
WATER LEVEL 9'  
TURNED #3 PUMP ON.  
DAVE RODDY

KCSlip4 67979

SEA436070

Thursday, July 18, 1968

200th day - 166 days to follow

8:05 A.M. Checking Station  
Pump #1 & #3 running  
Pump #2 under repair  
WATER LEVEL 5-5  
FRANK HARDING

9:45 Replaced internal parts of #2 pump  
Put sleeve in face plate & replaced  
seal - Pumping

#3 off → E. Brannon & T. Long  
Wendy & Lee

12:30 Turned out wood & other debris from  
wet well - WATER LEVEL 11-2'  
Turned on pumps #1, 2 & 3 - water level  
now 7-8'

FRANK HARDING & DAVE RODDEY

3:20 P.M.  
PUMPS #1, #2, #3 Running  
WATER LEVEL 6-0  
TURNED #3 PUMP OFF.  
DAVE RODDEY

Friday, July 19, 1968

201st day - 165 days to follow

8:05 A.M. Checking Station  
Pumps #1, #2 off running - #3 off  
WATER LEVEL 8-2'  
FRANK HARDING

12:45 Checked Station  
Pumps #1, #2 running - #3 off  
WATER LEVEL 8-0'  
FRANK HARDING

3:30 P.M. CHECKED STATION  
PUMPS #1, #2 RUNNING  
PUMP #3 OFF  
WATER LEVEL - 8.0'  
DAVE RODDEY

KCslip4 67980

SEA436071

Saturday, July 20, 1968

202nd day - 164 days to follow

8:35 AM Checking Station

Shut #1 pump down due to overheating  
#2 pump running - #3 off  
Water level 5-2'

Frank Harding

9:15 AM Cleaned eggs from #1 pump  
Water level 6-0'

Frank Harding

1:00 PM Water level 9-2' Turned on  
#3 pump. #3 & #2 running

Frank Harding

2:00 PM took section from intake pipe  
& cleared - found small pieces of rag  
keeping intake valve from closing fully -  
during time of priming - after cleaning  
everything, finally got it to go - now  
running pumps #1, & #2 - #3 pump off  
3:00 PM Water level 8-0'

Frank Harding

3:45 PM Checking Station  
Pumps #1 & #2 running - #3 off  
Water level 8-2'

Frank Harding

Sunday, July 21, 1968

203rd day - 163 days to follow

8:15 AM Checking Station

Shut off #2 pump - #3 off  
#1 pump running Water level 3-4'  
Frank Harding

12:30 PM Checking Station

turned on #2 pump - Water level 8-3'  
pumps #1 & #2 running

Frank Harding

5:00 PM  
Checked Station

#1 & #2 pumps running  
Water level 5-0'

KCslip4 67981

SEA436072

Monday, July 22, 1968

204th day - 162 days to follow

10:00 A.M. CHECKED STATION  
#1 PUMP OVERHEATED - TURNED IT OFF.  
#2 PUMP RUNNING  
#3 PUMP OFF - TURNED IT ON PUMPING DR.  
WATER LEVEL - 7.2'  
DAVE RODDIE

10:20 A.M.  
REMOVED ROOF FROM #1 PUMP  
PUMPS #1, #2 RUNNING  
WATER LEVEL - 7.8 FT.

DAVE RODDIE & ALAN AKERSTROM

3:45 PM Checked station  
#1 & #2 pump running  
water level 8' c' feet  
E. D. Roddick

Tuesday, July 23, 1968

205th day - 161 days to follow

8:17 A.M. CHECKED STATION  
PUMPS #1, #2 RUNNING  
PUMP #3 OFF  
WATER LEVEL - 4.9'  
DAVE RODDIE

0830

Shut flow off at Chelan Reg;  
W. Michigan Reg; and W. marginal  
way P.S. Pumped 54" influent  
line down for inspection. The  
line from the siphon to interim  
station could not be entered more  
than 20' due to sludge deposit  
down stream of siphon outlet  
structure. Removed bags from  
#1 - 3 times; #2 - 3 times;  
#3 - 2 times. Removed several  
pieces of wool from wet well.  
The 54" line from interim st. to  
new station checked out O.K.  
Flow turned back into line  
at about 12:30

E. D. Roddick  
3:30 P.M. PUMPS #1, #2, #3 RUNNING. TURNED OFF #3.  
WATER LEVEL - 6.8' - DAVE RODDIE

KCslip4 67982

SEA436073

Wednesday, July 24, 1968

206th day - 160 days to follow

8:115 A.M. Checking Station

Pumps #1, #2 running - #3 off

Water Level 5.4'

Frank Harding

1:30 P.M.

Checking station 8.5" full  
Water level 7.5"

E.W. Abougnare

3:38 P.M.

CHECKING STATION

PUMPS #1 & #2 RUNNING

PUMP #3 OFF

WATER LEVEL - 8.0'

DAVE RODDEY

Thursday, July 25, 1968

207th day - 159 days to follow

8:115 A.M. Checking Station

Pumps #1, #2 running - #3 off

Water Level 5.3'

Frank Harding

7:30 P.M. Checking Station

PUMPS #1 & #2 RUNNING

PUMP #3 OFF

WATER LEVEL - 7.2'

DAVE RODDEY

KCslip4 67983

SEA436074

Friday, July 26, 1968

208th day - 158 days to follow

8:20 A.M. Checking Station  
Pumps #1 & #2 running - #3 off  
WATER LEVEL 6.0'  
FRANK HARRING

10:45 A.M. shut off #3 pump to clean  
rags from channel

F.R.H.

11:30 A.M. Turned #2 back on - WATER LEVEL 7.0'  
F.R.H.

3:30 P.M. CHECKING STATION  
PUMPS #1 & #2 RUNNING.  
PUMP #3 OFF  
WATER LEVEL - 8.2'  
DAVE RODDEY

Saturday, July 27, 1968

209th day - 157 days to follow

9:30A.M. CHECKING STATION  
PUMPS #1 & #2 PUMPING  
PUMP #3 OFF  
WATER LEVEL - 5.4'  
DAVE RODDEY

4:00P.M. CHECKING STATION  
PUMP #1 & #2 RUNNING  
PUMP #3 OFF  
WATER LEVEL - 7.6'  
DAVE RODDEY

KCslip4 67984

SEA436075

Sunday, July 28, 1968

210th day - 156 days to follow

9:00 A.M. CHECKING STATION  
PUMPS #1 & #2 PUMPING  
PUMP #3 OFF  
WATER LEVEL - 2.8'  
DAVE RODDEY

3:30 A.M. CHECKING STATION  
PUMPS #1 & #2 PUMPING  
PUMP #3 OFF  
WATER LEVEL - 8.0'  
DAVE RODDEY

Monday, July 29, 1968

211th day - 155 days to follow

8:25 A.M. Checking Station  
Pumps #1 & #2 running - #3 off  
WATER LEVEL 5.8'  
FRANK HARDING

2:25 P.M. Checking Station  
Pumps #1 & #2 running - #3 off  
WATER LEVEL 9.0'  
Frank Harding

3:30 P.M. Checking Station  
Pumps #1 & #2 running - #3 off  
Water level 8.3'  
Frank Harding

KCSlip4 67985

SEA436076

Tuesday, July 30, 1968

212th day - 154 days to follow

8:20 A.M. Checking Station

Pumps #1 & #2 running - #3 off  
WATER LEVEL 6.4'

Frank Harding

10:40 A.M. Checking Station

Pumps #1, #2 running - #3 off  
WATER LEVEL 7.8'

Frank Harding

3:30 P.M. Checking Station

Pumps #1, #2 running - #3 off  
WATER LEVEL 8.3'

Frank Harding

Wednesday, July 31, 1968

213th day - 153 days to follow

Last Day for employers to file quarterly Social Security Tax Return  
and Wage Report, covering three previous calendar months.

8:15 A.M. Checking Station

Pumps #1, #2 running - #3 off  
WATER LEVEL 6.4'

Frank Harding

11:45 A.M.

WASHED DOWN ALL PUMPS, PUMPS #1 & #2 PUMPING.  
WATER LEVEL - 7.2'

DAVE RODD

12:45 Checking Station

Pumps #1, #2 running - #3 off  
WATER LEVEL 7.9'

Frank Harding

3:35 PM CHECKING STATION

PUMPS #1 & #2 PUMPING

PUMP #3 OFF

WATER LEVEL - 8.4'

DAVE RODD

KCslip4 67986

SEA436077

Thursday, August 1, 1968

214th day - 152 days to follow

8:20 A.M. Checking Station  
PUMPS #1, #2 PUMPING - #3 OFF  
WATER LEVEL 6.8'  
DAVE RODDY

12:40 <sup>P.M.</sup> Checking Station  
Pumps #1, #2 running - #3 off  
Water Level 8.0'  
Frank Harding

3:30 P.M. Checking Station  
Pumps #1 & #2 running - #3 off  
Water Level 8.2'  
Frank Harding

Friday, August 2, 1968

215th day - 151 days to follow

8:05 A.M. Checking Station  
Pumps #1, #2 running - #3 off  
WATER LEVEL 6.8'  
Frank Harding

3:40 P.M. Checking Station  
Pumps #1, #2 running - #3 off  
Water level 8.2  
Frank Harding

KCslip4 67987

SEA436078

Saturday, August 3, 1968

216th day - 150 days to follow

7:30 AM

Checking Station  
Pumps #1 & #2 running  
" #3 off  
Water level 5.6'

Clarence W. Walker

3:00 PM

Checking Station  
Pumps #1 & #2 running  
" #3 off  
Water Level 6.2'

Clarence W. Walker

Sunday, August 4, 1968

217th day - 149 days to follow

7:20 AM

Checking Station  
Pump #1 & #2 running  
Pump #3 off  
Water level 3.8'

Clarence W. Walker

3:10 PM

Checking Station  
Pumps #1 & #2 running  
Pump #3 off  
Water level 6.6'

Clarence W. Walker

KCslip4 67988

SEA436079

Monday, August 5, 1968

218th day - 148 days to follow

AM  
8:05 Checking Station

Shut off Pump #1, because of Loud  
Thumping noise. (going to check out) - #2  
running - #3 off Water level 3.5'

AM  
Frank Haroring

8:45 Checked #1 pump. Found it to be full  
of eggs. cleaned & started again.

Water level 6-4'

Frank Haroring

AM  
3:20 Checking Station

Pumps #1, & #2 running - #3 off -  
Water level 8.2'

Frank Haroring

Tuesday, August 6, 1968

219th day - 147 days to follow

7:55 A.M. Checking Station

Pumps #1, & #2 running - #3 off  
Water level 6.7'  
Frank Haroring

3:20 P.M. Checking Station

Pumps #1, & #2 running - #3 off  
Water level 8.3'

Frank Haroring

KCslip4 67989

SEA436080

Wednesday, August 7, 1968

220th day - 146 days to follow

7:50 A.M. Checking Station  
Pumps #1 & #2 running - #3 off  
WATER LEVEL 6.7'  
FRANK HARDING

11:30 A.M. CHECKING STATION  
PUMPS #1, #2 PUMPING - #3 OFF  
WATER LEVEL - 7.4'  
DAVE RODDEY

3:37 P.M. CHECKING STATION  
PUMPS #1, #2 PUMPING - #3 OFF  
WATER LEVEL - 8.2'  
DAVE RODDEY

Thursday, August 8, 1968

221st day - 145 days to follow

7:50 A.M. Checking Station  
Pumps #1, #2 running - #3 off  
WATER LEVEL 6.3'  
FRANK HARDING

3:40 P.M. CHECKING STATION  
PUMPS #1, #2 PUMPING - #3 OFF  
WATER LEVEL - 8.0'  
DAVE RODDEY

KCSlip4 67990

SEA436081

Friday, August 9, 1968

222nd day - 144 days to follow

7:50 A.M. Checking Station  
Pumps #1 & #2 running - #3 off  
WATER LEVEL 5.5'  
Frank Harding

11:35AM. Checking Station  
PUMPS #1, #2 Pumping - #3 off  
WATER LEVEL 6.4'  
DAVE RODASY

3:30 P.M. Checking Station  
Pumps #1 & #2 running - #3 off  
WATER LEVEL 8-1'  
Frank Harding

Saturday, August 10, 1968

223rd day - 143 days to follow

7:50 A.M. Checking Station  
Pumps #1 & #2 running - #3 off  
WATER LEVEL 6.3'  
Frank Harding

10:40 A.M. Checking Station  
#2 pump warm - opened & took out  
rager - #1 & #2 running.  
Water level 7.0' Frank Harding

3:30 P.M. Checking Station  
Pumps #1 & #2 running - #3 off  
WATER LEVEL 7-7'  
Frank Harding

KCSlip4 67991

SEA436082

Sunday, August 11, 1968

224th day - 142 days to follow

8:00 AM Checking Station

Pumps #1 & #2 running - #3 off  
Water level 6.0'

Frank Harding

3:00 PM Checking Station

Turned #1 pump off & started #3  
pump #2 & #3 running - #1 off.  
Water level 6.8'

Frank Harding

Monday, August 12, 1968

225th day - 141 days to follow

8:15 AM Checking station  
all three pumps on on line  
water level 5.0 feet.  
checked oil levels - OK

Tom Sawyer

3:00 PM

Checked station  
all 3 pumps on  
turned off #1  
Water level 7.8'

Laurence W. Walker

KCSlip4 67992

SEA436083

Tuesday, August 13, 1968

226th day - 140 days to follow

8:00 A.M. Checking Station

Pump #2 & #3 running - #1 off  
Water level 6.0'

Frank Harding

12:40 P.M. Checking Station

Pumps #2 & #3 running - #1 off  
Water level 7.2'

Frank Harding

3:32 P.M. CHECKING STATION

PUMPS #2, #3 PUMPING - #1 OFF  
WATER LEVEL 8.0'

DAVE RODNEY

Wednesday, August 14, 1968

227th day - 139 days to follow

8:00 A.M. Checking Station

Turned pump #1 on because of high  
water level of 13.0'

Pumps #1, #2 & #3 running  
Water level 10.8'

Frank Harding

8:30 A.M. Turned #1 pump off -

water level 13.2'

Frank Harding

1:40 P.M. Checking Station

Pumps #2 & #3 running - #1 off  
Water level 13.0'

Frank Harding

3:30 P.M. Checking Station

Pumps #2 & #3 running - #1 off  
Water level 13.2'

Frank Harding

KCSlip4 67993

SEA436084

Thursday, August 15, 1968

228th day - 138 days to follow

Assumption of the Blessed Virgin Mary

8:00 A.M. Checking Station  
Pumps #2 & #3 running - #1 off  
Water level 6-8'  
Frank Harding

3:40 P.M. Checking Station  
Pumps #2 & #3 running - #1 off  
Water level 7-8'  
Frank Harding

Friday, August 16, 1968

229th day - 137 days to follow

8:00 A.M. Checking Station  
Pumps #2 & #3 running - #1 off  
Water level 6-0'  
Frank Harding

11:15 A.M. Checking Station  
PUMPS #2, #3 PUMPING - #1 OFF  
WATER LEVEL - 7.0'  
DAVE RODDY

3:40 P.M. Checking Station  
PUMPS #2, #3 PUMPING - #1 OFF  
WATER LEVEL - 7.8'  
DAVE RODDY

KCslip4 67994

SEA436085

Saturday, August 17, 1968

230th day - 136 days to follow

8:30 A.M. CHECKING STATION  
PUMPS #2, #3 PUMPING - #1 OFF  
WATER LEVEL - 5.4'

DAVE RODDEY

3:25 P.M. CHECKING STATION  
PUMP #2, #3 PUMPING - #1 OFF  
WATER LEVEL - 7.0'

DAVE RODDEY

Sunday, August 18, 1968

231st day - 135 days to follow

8:35 A.M. CHECKED STATION  
PUMPS #2, #3 PUMPING - #1 OFF  
PUMP #3 KNOCKING - TURNED IT OFF - TURNED ON #1.  
PUMPS #1, #2 PUMPING - #3 OFF  
WATER LEVEL - 5.0'

DAVE RODDEY

3:30 P.M. CHECKED STATION  
PUMPS #1, #2 PUMPING  
PUMP #3 OFF  
WATER LEVEL - 6.8'

DAVE RODDEY

KCslip4 67995

SEA436086

Monday, August 19, 1968

232nd day - 134 days to follow

8:00 AM Checking Station

Turned off #1 pump because of  
over heating - will check.  
#2 running - #3 off turned on  
Water level 6-9'

Frank Harding

11:00 AM Cleared sage from #1 pump  
#1, #2 & #3 pumps running - #2 off  
Water 8-0' Frank Harding

11:30 AM Turned on #2 pump. - #1, #2 & #3  
pumps running Water level 6-6'

Frank Harding

12:40 PM Checking Station

Pumps #1, #2 & #3 running  
Water level 6-4'

Frank Harding

Turned off #3 pump - #1 & #2 running  
Water level 8-2'

Frank Harding

Tuesday, August 20, 1968

233rd day - 133 days to follow

8:00 AM Checking Station

Turned on #2 pump - #1, #2 & #3  
pumps running - Water level 5-8'  
Frank Harding

12:45 Checking Station

Pumps #1, #2 & #3 running  
Water level 4-5

Frank Harding

3:40 Checking Station

Turned off #3 pump - #1 & #2  
running - Water level 3-2'

Frank Harding

KCslip4 67996

SEA436087

Wednesday, August 21, 1968

234th day - 132 days to follow

7:50 A.M. Checking Station  
Pumps #1 & #3 running - #2 off  
Water level 5-6'

8:20 A.M. Cleaned rags from #3  
pump - Pumps #1, #2 & #3 running  
Water level 5-3'

3:30 A.M. Checking Station  
Turned #2 pump off - #1 & #3 pumps  
running Water level 3-6'  
Frank Harding

Thursday, August 22, 1968

235th day - 131 days to follow

6:00 A.M. CHECKING STATION  
PUMPS #1, #3 RUNNING - #2 OFF  
WATER LEVEL - 5.4'

DAVE RODDY

3:00 P.M. -CHECKING STATION  
PUMPS #1-#3 RUNNING -#2 OFF  
WATER LEVEL - 7.0'

DAVE RODDY

KCslip4 67997

SEA436088

Friday, August 23, 1968

236th day - 130 days to follow

7:50 AM Checking Station  
Pumps #1 & #3 running - #2 off  
Water level 7-8'  
Frank Harding

3:30 PM Checked Station  
Pumps #1 & #3 running #2 off  
Water Level 8.2'  
Removed Rags and links from  
#2 -  
Pumps #1 & #2 running #3 off

Clarence W. Walker

Saturday, August 24, 1968

237th day - 129 days to follow

8:30 AM  
Checking Station  
#1 & #2 pumps running  
#3 pump off  
Water level 8.'

Clarence W. Walker

3:30 PM  
Checking Station  
#1 & #2 pumps running  
#3 pump off  
Water level 8.2'

Clarence W. Walker

KCSlip4 67998

SEA436089

Sunday, August 25, 1968

238th day - 128 days to follow

8:20 AM

Checking Station

#1 & #2 pumps running

#3 pump off

Water level 7-6'

Turned off #2 pump high  
wet well

Clarence W. Walker

3:00 PM

Checking Station - Heavy Rain

#1 pump running

#2 & #3 pumps off - high well(wet)

Water level 10-6'

Clarence W. Walker

Monday, August 26, 1968

239th day - 127 days to follow

8:00 AM Checking Station

Turned on pumps #2 & #3 - water level

12-2 - Pumps #1, #2 & #3 running

Water level 7-2'

Frank Harding

10:00 AM Turned #2 pump off because of  
high water level in main wet well -

pumps #1 & #3 running - water level 6-5

Frank Harding

3:30 PM Checking Station

Turned #1 pump off - #1, #2 off

#3 running - Water level 9-2

Frank Harding

KCslip4 67999

SEA436090

Tuesday, August 27, 1968

240th day - 126 days to follow

8:00 AM Checking Station

Pumps #1 & #2 off - #3 running -  
WATER LEVEL 13-4'

Frank Harding

8:15 AM Turned pumps #1 & #2 on -

#1, #2 & #3 running - water level 9-4'

Frank Harding

3:30 PM Checking Station

Turned #1 & #2 pump off - #3 running -  
WATER LEVEL 9-3

Frank Harding

Wednesday, August 28, 1968

241st day - 125 days to follow

7:50 AM Checking Station

Turned pumps #1 & #2 on - #1, #2 & #3  
running - water level 5-8'

Frank Harding

3:30 PM Checking Station

Turned pumps #2 & #3 off - #1 running -  
WATER LEVEL 7-8

Frank Harding

KCSlip4 68000

SEA436091

Thursday, August 29, 1968

242nd day - 124 days to follow

7:50 A.M. Checking Station

- turned pumps #2 & #3 on - #1, #2 & #3 running  
running - water level 5-6'

Frank Harding

3:30 P.M. Checking Station

- turned #2 pump off - #1, #2 & #3 running  
water level 4-0'

Frank Harding

Friday, August 30, 1968

243rd day - 123 days to follow

8:10 A.M. Checking Station

- turned #2 pump on - #1, #2 & #3 running  
water level 2-6'

Frank Harding

3:30 A.M. Turned #2 & #3 pumps off,  
Low water level - #1 pump running -  
water level 3-0'

Frank Harding

3:15 Checking Station

- turned #2 pump on - #1, #2 & #3 running -  
#3 pump off - water level 7-8'

Frank Harding

KCslip4 68001

SEA436092

Saturday, August 31, 1968

244th day - 122 days to follow

3:30 A.M. CHECKED STATION

PUMPS #1, #2 RUNNING

PUMP #3 OFF

WATER LEVEL - 6'

DAVE RODDEY

3:40 P.M. CHECKED STATION

PUMPS #1, #2 RUNNING - #3 OFF

WATER LEVEL - 7.8'

DAVE RODDEY

Sunday, September 1, 1968

245th day - 121 days to follow

3:30 A.M.

CHECKED STATION

PUMPS #1, #2 RUNNING - #3 OFF

WATER LEVEL - 7.8'

DAVE RODDEY

3:30 P.M.

CHECKED STATION

PUMPS #1, #2 RUNNING - #3 OFF

WATER LEVEL 7.8'

DAVE RODDEY

KCslip4 68002

SEA436093

Monday, September 2, 1968

246th day - 120 days to follow

8:00 A.M. CHECKED STATION Labor Day

PUMPS #1, #2 RUNNING - #3 OFF

WATER LEVEL - 4.0'

DAVE RODDEY

3:30 P.M.

PUMP #1 OVERHEATED - TURNED IT OFF

TURNED ON PUMP #3 - PUMPING O.K.

PUMPS #2, #3 NOW RUNNING - #1 OFF

WATER LEVEL - 7.4'

DAVE RODDEY

Tuesday, September 3, 1968

247th day - 119 days to follow

8:00 A.M. CHECKING STATION

PUMPS #2 & #3 RUNNING - #1 OFF

WATER LEVEL 3-6'

FRANK HARDING

11:15 A.M. TOOK RAGS FROM #1, & #2  
PUMPS - #1, & #2 RUNNING - #3  
ALSO HOT, TURNED OFF.  
WATER LEVEL 7-2'

FRANK HARDING

12:30 P.M. TOOK RAGS FROM #3 PUMP -  
PUMPS #1, #2 & #3 RUNNING -  
WATER LEVEL 5-6'

FRANK HARDING

3:45 P.M. CHECKING STATION

TURNED #3 PUMP OFF - #1 & #2 RUNNING -  
WATER LEVEL 5-2'

FRANK HARDING

KCSlip4 68003

SEA436094

Wednesday, September 4, 1968

248th day - 118 days to follow

7:50 A.M. Checking Station

Turned #3 pump on - #1, #2 & #3  
running - WATER LEVEL 5-7'

Frank Harding

3:30 P.M. Checking Station

#1, pump turned off, running hot -  
#3 " " making noise -  
#2 " running - water level 8-2'  
Frank Harding

Thursday, September 5, 1968

249th day - 117 days to follow

8:30 A.M. Checking Station

Turned #3 pump - #2 & #3 running -  
checked #1, for rags & cleaned out  
#1, running - water level 5-4'

Frank Harding

1:00 P.M. Checking Station

Pumps #1, #2 & #3 running  
WATER LEVEL 5-6'

Frank Harding

1:45 Turned #1, & #3, pumps off - maintenance  
crew working on #2 pump motor at  
headworks dry-well - water level 8-8'

Frank Harding

3:40 P.M. Checking Station

#1, & #3, pumps off - #2 running -  
water level 9-2'

Frank Harding

KCSlip4 68004

SEA436095

Friday, September 6, 1968

250th day - 116 days to follow

7:55 Checking Station  
#1 & #3 pumps off - #2 running -  
WATER LEVEL 8-9' - Still working on  
#2 pump motor at headworks dry well  
Frank Harding

3:30 P.M. Checked Station  
PUMP #2, RUNNING, #1, #3 OFF  
WATER LEVEL - 9.0'  
DAVE RODDIE

Saturday, September 7, 1968

251st day - 115 days to follow

5:10 A.M. Checking Station  
Three pumps #1 & #3 off - #1, #2 & #3  
running - water level 5-8'  
Frank Harding

12:45 Checking Station  
Pumps #1, #2 & #3 running -  
water level 4-8'  
Frank Harding

3:45 Checking Station  
Shut off #2 & #3 pumps - #1 running -  
WATER LEVEL 3-5"  
Frank Harding

KCSlip4 68005

SEA436096

Sunday, September 8, 1968

252nd day - 114 days to follow

8:40 A.M. Checking Station

Turned on pumps #2 & #3 -

#1, #2 & #3 pumps running

WATER LEVEL 5-8'

Frank Harding

12:40 P.M. Checking Station

Pumps #1, #2 & #3 running -

WATER LEVEL 4-5'

Frank Harding

1:50 Shut #1 & #3 pumps off - #2 running

WATER LEVEL 3-8'

Frank Harding

3:40 P.M. Checking Station

#2 pump running - #1 & #3 off -

WATER LEVEL 8-2'

Frank Harding

Monday, September 9, 1968

253rd day - 113 days to follow

8:30 A.M.

Admission Day (California)

CHECKED STATION

#2 PUMP RUNNING #1 #3 OFF

TURNED ON #3 PUMP

WATER LEVEL - 8.0'

DAVE RODDEY

3:30 P.M. CHECKED STATION

PUMPS #2, #3 ON

PUMP #1 OFF

WATER LEVEL - 8.0'

DAVE RODDEY

KCslip4 68006

SEA436097

Tuesday, September 10, 1968

254th day - 112 days to follow

8:10 A.M. Checking Station  
Turned #3 pump off (heating) -  
#1 pump off - #2 running  
WATER LEVEL 3'-0'

Frank Harding  
8:30 A.M. Took eggs from #3 pump -  
Pumps #1, #2 & #3 running -  
WATER LEVEL 5'-5"

Frank Harding  
3:35 A.M. CHECKING STATION  
PUMPS #1, #2, #3 PUMPING  
TURNED OFF #3 PUMP - MAKING NOISE.  
WATER LEVEL - 3'6"  
DAVE RODDIE

Wednesday, September 11, 1968

255th day - 111 days to follow

3:30AM CHECKED STATION  
PUMPS #1, #2 RUNNING - #3 OFF  
WATER LEVEL - 5'0"  
DAVE RODDIE

11:10 A.M. CHECKED STATION  
PUMPS #1, #2 RUNNING - #3 OFF  
SINKPT FLOOR  
WATER LEVEL - 5'0"  
DAVE RODDIE

3:30 P.M. Checking Station  
Pumps #1, #2 running - #3 off -  
water level 8'-8"  
Frank Harding

KCslip4 68007

SEA436098

Thursday, September 12, 1968

256th day - 110 days to follow

8:00 A.M. Checking Station  
Pumps #1 & #2 running - took  
eggs from #3 pump & started -  
Pumps #1, #2 & #3 running -  
WATER LEVEL 5-3'

Frank Harding

12:30 P.M. Checking Station

Pumps #1 & #2 running - #3 auto-  
off - WATER LEVEL 3-3'

Frank Harding

3:30 P.M. Checking Station

#1 pump shut off because of eggs -  
Pumps #2 & #3 running -  
WATER LEVEL 2-4'

Frank Harding

Friday, September 13, 1968

257th day - 109 days to follow

7:50 A.M. Checking Station  
Pumps #2 & #3 running - water  
LEVEL 4-0' - Took eggs from #1 -  
Pumps #1, #2 & #3 running - water  
LEVEL 4-2'

Frank Harding

12:30 P.M. Checking Station

Pumps #1 & #2 running - #3 auto-off  
WATER LEVEL 2-9'

Frank Harding

3:30 P.M. Checking Station

Turned Pumps #1 & #3 off - #2 running -  
WATER LEVEL 4-0'

Frank Harding

KCSlip4 68008

SEA436099

Saturday, September 14, 1968

258th day - 108 days to follow

8:55 A.M. CHECKING STATION

PUMP #2 RUNNING - #1, #3 OFF

WATER LEVEL - 9.0'

DAVE RODDEY

3:30 P.M. CHECKING STATION

PUMP #2 RUNNING PUMPS #1, #3 OFF

WATER LEVEL - 12.6'

DAVE RODDEY

Sunday, September 15, 1968

259th day - 107 days to follow

9:30 A.M.

CHECKING STATION

PUMP #2 RUNNING - #1, #3 OFF

TURNED #1 ON BECAUSE OF LOW FLOW AT PLANT.

WATER LEVEL - 7.6'

DAVE RODDEY

3:40 P.M. CHECKING STATION

PUMPS #1, #2 RUNNING - #3 OFF

TURNED #1 OFF BECAUSE OF RAIN

WATER LEVEL - 7.2'

DAVE RODDEY

KCslip4 68009

SEA436100

Monday, September 16, 1968

260th day - 106 days to follow

7:50 A.M. Checking Station

Took RAGS from #1 pump -  
Pumps #1, #2 & #3 running -  
WATER LEVEL 5-6'

Frank Harding

12:30 P.M. Checking Station

Pumps #1, #2 & #3 running  
WATER LEVEL 5-0'

Frank Harding

3:40 P.M. Checking Station

Turned pumps #1 & #2 off -  
#3 running - WATER LEVEL 4-9'  
Frank Harding

Tuesday, September 17, 1968

261st day - 105 days to follow

7:55 A.M. Checking Station

Turned on pumps #1 & #2 -

#1, #2 & #3 running - WATER LEVEL 5-8'  
Frank Harding

12:30 Checking Station

Pumps #1, #2 & #3 running -  
WATER LEVEL 6-0'

Frank Harding

3:20 P.M. Checking Station

Turned #2 pump off - #1, & #3  
running - WATER LEVEL 7-8'

Frank Harding

KCslip4 68010

SEA436101

Wednesday, September 18, 1968

262nd day - 104 days to follow

7:30 AM Checking Station

Pumps #1 & #3 running - #2 off -  
water level 9-3'

Frank Harding

12:30 AM Checking Station

Pumps #1 & #3 running - #2 off -  
water level 7-9'

Frank Harding

3:20 P.M Checked Station

Pumps #1 & #3 running

Pump #2 off

water level 7-8'

Clarence Hall

Thursday, September 19, 1968

263rd day - 103 days to follow

8:00 AM Checking Station

switched from #1 to #2 pump -

Pumps #2 & #3 running - #1 off -

water level 7-6'

Frank Harding

10:30 AM

Turned #1 pump on - #1, #2 & #3 running -  
water level 5-8'

Frank Harding

12:45 P.M. Checking Station

Pumps #1, #2 & #3 running -

water level 5-6'

Frank Harding

3:15 PM Checking Station

TURNED #1 & #2 pumps off due to  
forecast of rain - #3 pump running -  
water level - 9-0

Frank Harding

KCSlip4 68011

SEA436102

Friday, September 20, 1968

264th day - 102 days to follow

8:00 AM Checking Station  
Turned pumps #1, #2 on.  
#1, #2 & #3 running - water level 3-2'  
Frank theodolite

1:28 P.M.  
TURNED OFF ALL 3 PUMPS IN ORDER TO  
REMOVE RAGS FROM CHANNEL INTO PLANT.  
WATER LEVEL - 2.6' DAVE RODDY

1:55 P.M.  
TURNED ON ALL 3 PUMPS, TURNED OFF #3  
WATER LEVEL - 7.2' / MOTOR RUNNING HOT  
DOVE RODDY

2:55 P.M. Checking station  
Checking #3 pump for overheat  
seems to be ok.

3:30 P.M. Checking station  
PUMPS #1, #2, #3, RUNNING - #3 seems OK.  
WATER LEVEL - 2.8'  
TURNED OFF #2, #3 PUMPS FOR NIGHT.  
DAVE RODDY

Saturday, September 21, 1968

265th day - 101 days to follow

8:15 AM Checked  
Pump 1 running  
pumps #2 & #3 off  
Water level 5.8'

Clarence W. Walker

3:20 PM  
checked station  
Pump #3 running  
Pumps #2 & #3 off  
Water 6'

Clarence W. Walker

KCSlip4 68012

SEA436103

Sunday, September 22, 1968

266th day - 100 days to follow

8:30 AM

Pump #1 running  
Pumps #2 & #3 off  
Water Level 6'  
Turned on #2

Clarence W. Walker

3:15 PM

Pump #1 & #2 running  
Pump #3 off  
Water level 4.8'  
Turned #2 off

Clarence W. Walker

Monday, September 23, 1968

267th day - 99 days to follow

Rosh Hashonah - First Day of Jewish New Year

8:30 AM Checking Station

Turned #3 pump on - #1 & #3 running -  
#2 pump off - WATER LEVEL 4.8'  
Frank Hardin

9:15 AM Turned #2 pump on - #1, #2 & #3 running -  
WATER LEVEL 3.3'

Frank Hardin

12:40 PM Checking Station

Pumps #1, #2 & #3 running -  
WATER LEVEL 3.0'

Frank Hardin

3:30 PM Checking Station

Turned #1 & #3 pumps off - #2 running -  
WATER LEVEL 2.8'

Frank Hardin

KC Slip 4 68013

SEA436104

Tuesday, September 24, 1968

268th day - 98 days to follow

Rosh Hashonah - Second Day of Jewish New Year

7:50 A.M. Checking Station  
Turned on #1 & #3 pumps -  
#1, #2 & #3 running -  
water level 3-4'

Frank Harding

12:30 P.M. Checking Station  
Turned #3 pump off because of work  
being done on #1 pump in drywell -  
#1 & #2 running - water level 4-6'

Frank Harding

1:15 P.M. Turned #3 pump back on - work in  
drywell finished - water level 3-5'

Frank Harding

3:25 P.M. Checking Station  
Turned #2 & #3 pumps off - #1 running -  
water level 3-0'

Frank Harding

Wednesday, September 25, 1968

269th day - 97 days to follow

9:30 A.M. CHECKING STATION  
#1 PUMP RUNNING - #2, #3 OFF  
TURNED ON #2 PUMP - #1, #2 NOW RUNNING  
WATER LEVEL - 7.0'  
DAVE RODDIE

12:30 P.M. Checking Station

Turned #3 pump on - #1, #2 & #3 running -  
water level 3-7'

Frank Harding

3:30 P.M. CHECKING STATION  
PUMPS #1, #2, #3 RUNNING  
WATER LEVEL - 3-4'  
TURNED PUMPS #2, #3 OFF FOR NITE.  
DAVE RODDIE

KCslip4 68014

SEA436105

Thursday, September 26, 1968

270th day - 96 days to follow

8:00 A.M. Checking Station

Turned on #2 & #3 pumps -  
#1, #2 & #3 running  
WATER LEVEL 3-6'

Frank Harding

12:40 P.M. Checking Station

Turned #3 pump off (noisy) -  
#1 & #2 running - WATER LEVEL 4-6'  
Frank Harding

3:00 Checking Station

Removed sticks & rags from #3 pump &  
Turned back on - Turned #1 & #2 off -  
#3 pump running - WATER LEVEL 6-5'

Frank Harding

Friday, September 27, 1968

271st day - 95 days to follow

8:00 A.M. Checking Station

Turned on #1 & #2 pumps -  
#1, #2 & #3 running - WATER LEVEL 3-8'

Frank Harding

12:40 P.M. Checking Station

Pumps #1, #2 & #3 running -  
WATER LEVEL 2-6'

Frank Harding

3:30 A.M. CHECKING STATION

PUMPS #1, #2, #3 RUNNING  
TURNED #3 OFF FOR NITE.  
WATER LEVEL 3-0'

DAVE RODDY

KC Slip 4 68015

SEA436106

Saturday, September 28, 1968

272nd day - 94 days to follow

8:10 A.M. Checking Station

Turned #3 pump on - #1 running  
#2 & #3 in auto-off -  
water level 2-3'

Frank Harding

Sunday, September 29, 1968

273rd day - 93 days to follow

8:15 A.M. Checking Station

Turned #2 pump on - #1, & #2 running -  
#3 pump on auto-off -  
water level 3-0'

Frank Harding

1:00 P.M. Checking Station

Pumps #1, #2 & #3 running -  
water level 2-7'

Frank Harding

1:14 P.M. Checking Station

Pumps #1 & #2 running - #3 on auto-off -  
water level 3-8'

Frank Harding

3:15 P.M. Checking Station

Shut #2 pump off - #1 & #3 running -  
water level 4-0'

Frank Harding

3:15 P.M. Checking Station

Took range from #3 pump (primed) & shut  
off for the night - Pumps #1, & #2 running -  
water level 2-5'

Frank Harding

KCSlip4 68016

SEA436107

Monday, September 30, 1968

274th day - 92 days to follow

3:10 A.M.

CHECKING STATION

PUMP #1 RUNNING - P2 OFF ON AUTO, P3 OFF  
WATER LEVEL - 2.2'

DAVE RODDY

Tuesday, October 1, 1968

275th day - 91 days to follow

7:00 A.M. CHECKING STATION

PUMPS #1 RUN NIT - #2, #3 ON  
TURBO #2, #3 ON

WATER LEVEL - 7.0'

DAVE RODDY

3:30 P.M. CHECKING STATION

PUMPS P1, P2 Running - P3 OFF ON AUTO  
TURNED P3 OFF FOR NITE. ALSO P2.  
WATER LEVEL - 4.0'

DAVE RODDY

3:45 P.M. CHECKING STATION

PUMPS #1, 2 RUNNING - #3 OFF ON AUTO  
WATER LEVEL - 3.7'

TURNED PUMPS #2, P3 OFF FOR NITE  
DAVE RODDY

KC Slip 4 68017

SEA436108

Wednesday, October 2, 1968

276th day - 90 days to follow

7:50 A.M. Checking Station  
Turned Pumps #2 & #3 on -  
#1, #2 & #3 slow running -  
WATER LEVEL 4-2'

Frank Harding

12:40 Checking Station  
Pumps #1, #2 & #3 running hot -  
Took eggs & sticks from all 3 pumps,  
scrined & started - #1, #2 & #3 running  
WATER LEVEL 6-0'

CLEANED INTERM STATION

Frank Harding

3:25 P.M. Checking Station  
Turned #2 & #3 pumps off for the  
night - #1 pump running -  
WATER LEVEL 8-2'

Frank Harding

Thursday, October 3, 1968

277th day - 89 days to follow

7:50 A.M. Checking Station  
Turned Pumps #2 & #3 on -  
#1, #2 & #3 running - WATER LEVEL 5-0'  
Frank Harding

12:40 P.M. Checking Station  
Pumps #1, #2 & #3 running -  
WATER LEVEL 4-1'  
Frank Harding

3:30 P.M. CHECKING STATION  
PUMPS #1, #2 RUNNING, #3 OFF ON AUTO  
TURNED PUMP #3 OFF. TURNED #2 ON FOR NSK.  
WATER LEVEL - 2.8'

DAVE RODDY

KC Slip 4 68018

SEA436109

Friday, October 4, 1968

278th day - 88 days to follow

7:15 A.M. Checking Station

Turned #3 pump on - #1 & #3 running - #2 off  
WATER LEVEL 11-8'

Frank Harding

12:40 P.M. Checking Station

Pumps #1 & #3 running - #2 off  
WATER LEVEL 7-7'

Frank Harding

3:26 P.M. Checking Station

PUMPS #1, #3 Running - #2 off  
WATER LEVEL - 7-8'

TURNED #3 PUMP OFF FOR NITK,  
Dave Roddey

Saturday, October 5, 1968

279th day - 87 days to follow

8:30 A.M. CHECKING STATION

PUMP #1 RUNNING - #2, #3 OFF  
WATER LEVEL - 8-8'

TURNED #2 PUMP ON - #1, #2 NOW RUNNING - #3 OFF  
DAVE RODDEY

3:45 P.M. CHECKING STATION

PUMPS #1, #2 RUNNING - #3 OFF  
TURNED #1 PUMP OFF FOR NITK  
WATER LEVEL - 9-0!

DAVE RODDEY

KCslip4 68019

SEA436110

Sunday, October 6, 1968

280th day - 86 days to follow

8:00 A.M. Checking Station

#2 PUMP RUNNING, #1-#3 OFF

LEVEL #1, #3 OFF BECAUSE OF RAIN.

WATER LEVEL 8.0'

DAVE RODNEY

11:55 A.M. Checking Station

#2 PUMP RUNNING, #1-#3 OFF

WATER LEVEL - 9.0'

DAVE RODNEY

Monday, October 7, 1968

281st day - 85 days to follow

Succoth

8:10 A.M. Checking Station

Turned pumps #1, #3 on -

#1, #2 & #3 running - water level 5-8'

Frank Harding

12:45 P.M. Checking Station

Pumps #1, #2 & #3 running -

water level 5-3'

Frank Harding

2:30 P.M. Checking Station

Pumps #2 & #3 turned off because of

rain - #1 pump running -

water level 4-7'

Frank Harding

KCslip4 68020

SEA436111

Tuesday, October 8, 1968

282nd day - 84 days to follow

7:50 A.M. Checking Station

Pumps #2 & #3 turned on  
#1, #2 & #3 running -  
WATER LEVEL 5-9'

Frank Harding

12:40 P.M. Checking Station

Pumps #1, #2 & #3 running -  
WATER LEVEL 5-5'

Frank Harding

3:30 P.M. Checking Station

Turned #2 & #3 pumps off -  
#1, pump running - WATER LEVEL 5-4'

Frank Harding

Wednesday, October 9, 1968

283rd day - 83 days to follow

7:35 A.M. Checking Station

Pumps #2 & #3 turned on  
#1, #2 & #3 running -  
WATER LEVEL 5-8'

Frank Harding

9:30 A.M.

Checked #1, #2 & #3 pumps because of  
noise, both pumps okay.  
WATER LEVEL 6-2'

Frank Harding

3:35 P.M. Checking Station

PUMPS #1, #2, #3 RUNNING

PUMP #3 RANGING LOWLY - SHUT IT OFF

TURNED #2 PUMP OFF FOR NITE REVERSE RAIN.  
WATER LEVEL 2-6'

~~DAVE RADLEY~~  
#1 PUMP SUCKING AIR THRU SEAL PLUG TURNED  
IT OFF. #2 PUMP RUNNING.

DAVE RADLEY

KCSlip4 68021

SEA436112

Thursday, October 10, 1968

284th day - 82 days to follow

Friday, October 11, 1968

285th day - 81 days to follow

8:10 A.M. Checking Station

Dave Rooney checked & filled oil  
in seal plug, primed pump #1, & started -  
#3 pump cleared of eggs & sticks, primed  
& started - Pumps #1, #2 & #3  
running - WATER LEVEL 7-1  
Frank H. & Dave Rooney

3:50 P.M. Checking station

Shut down for 10 minutes  
for rag removal from  
downnel.  
Water level 5-8'  
td along.

4:10 P.M. ~~CHECKING STATION~~

PUMPS #1, #2, #3 RUNNING  
WATER LEVEL 4-2'  
PUMPS #2, #3 OFF FOR NITE  
DAVE ROONEY

7:50 Checking Station

Turmed #2 & #3 pumps on -  
#1, #2 & #3 running - WATER LEVEL 5-9'  
Frank Harding

12:00 P.M. Checking Station

Pumps #1, #2 & #3 running -  
WATER LEVEL 5-5'

Frank Harding

3:30 P.M. Checked Station

All pumps running  
Water level 4-8'  
Pumps #2 & #3 off for night

Clarence W. Walker

KCSlip4 68022

SEA436113

• Saturday, October 12, 1968  
286th day - 80 days to follow

Columbus Day

8:00 A.M.  
Checked Station  
Pump #1 running  
Pump #2 off - #2 turned on  
Water level 9'

Clarence H. Walker

3:00 P.M.  
Checked Station  
Pumps #1 & #2 running  
Pump #3 off  
Water level 7.8'  
Turned #2 off

Clarence H. Walker

Sunday, October 13, 1968  
287th day - 79 days to follow

8:00 A.M. - Hard Rain  
Checked Station  
Pump #1 running  
Pump #2 off  
Water level 9.6'

Clarence H. Walker

3:00 A.M.  
Checked Station  
Pump #1 running  
Pump #2 & #3 off  
Water level 10.9'

Clarence H. Walker

KC Slip 4 68023

SEA436114

Monday, October 14, 1968

288th day - 78 days to follow

8:10 AM Checking Station

Pumps on #2 & #3 pumps -  
#1, #2 & #3 running - water level 8'-0'  
Frank Harding

12:30 PM Checking Station

Pumps #1, #2 & #3 running -  
#1 pump sucking air -  
water level 6-0'  
Frank Harding

1:45 PM Checking Station

Set oil in #1 pump but still  
pumpers air (seal gone.) F. Harding

2:30 PM All 3 pumps running -  
water level 6-0'

Frank Harding

3:35 PM Checking Station

Shut #1 & #3 pumps off because  
of low forecast - #2 pump running -  
water level 9-0'

Frank Harding

Tuesday, October 15, 1968

289th day - 77 days to follow

8:10 AM Checking Station

Turned on #1 & #3 pumps -

#1 pump still sucking air -

Pumps #1, #2 & #3 running -  
water level 12-4' low 7-8'

Frank Harding

12:45 PM Checking Station

Pumps #1, #2 & #3 running -  
water level 6-0'

Frank Harding

3:40 PM Checking Station

Turned off #1 & #3 pumps (2:30pm) -  
#2 running - #3 pump should be  
checked in morning because of noise  
water level 5-2'

Frank Harding

KCSlip4 68024

SEA436115

Wednesday, October 16, 1968

290th day - 76 days to follow

7:45 AM. Checking Station

#2 pump running - turned on  
#1, pump - cleared eggs & sticks  
from #3 pump & started -  
Pumps #1, #2 & #3 running -  
water level 7-1'

Frank Harding

12:40 PM. Checking Station

Pumps #1, #2 & #3 running -  
water level 5-3'

Frank Harding

3:30 PM. Checking Station

Shut off #1 & #2 pumps because  
of rain forecast - #3 running -  
water level 4-1'

Frank Harding

Thursday, October 17, 1968

291st day - 75 days to follow

5:10 AM. Checking Station

- turned on #1, #2 pumps -  
#1, #2 & #3 running -  
water level 5-8'

Frank Harding

12:45 PM. Checking Station

Pumps #1, #2 & #3 running -  
water level 4-9'

Frank Harding

3:35 PM. Checking Station

Shut off #1, #2 pumps (forecast  
rain) - #3 pump running -  
water level 9-3'

Frank Harding

KCslip4 68025

SEA436116

Friday, October 18, 1968

292nd day - 74 days to follow

7:55 AM Checking Station

Turned on #1, & #2 pumps  
#1, #2 & #3 running -  
water level 8-5'

Frank Harding

11:15 AM Checking Station

Pumps #1, #2 & #3 running -  
water level 6-0'

Frank Harding

2:00 PM - Shut off #1 & #3 pumps  
to clean cage from channel

water level 9-1'

Frank Harding

3:35 Checking Station

Pumps #1, & #3 off - #2 running -  
(rain) water level 9-3'

Frank Harding

Saturday, October 19, 1968

293rd day - 73 days to follow

See 7:55 Checking Station

Turned on #1, & #3 pumps on -  
Pumps #1, #2 & #3 running -  
water level 5-9'

Frank Harding

12:45 PM Checking Station

Pumps #1, #2 & #3 running -  
#1 pump still sucking air -  
water level 6-2'

Frank Harding

3:45 PM Checking Station

Turned off #1, & #2 pumps (rain) -  
#3 pump running -  
water level 9-4'

Frank Harding

KCslip4 68026

SEA436117

Sunday, October 20, 1968

294th day - 72 days to follow

7:50 AM Checking Station

Turboed on #1 & #2 pumps  
#1, #2 & #3 running -  
water level 7-8'

Frank Harding

12:45 PM Checking Station

Pumps #1, #2 & #3 running -  
water level 6-1'

Frank Harding

3:45 PM Checking Station

Turboed off, pumps #1, & #3 -  
pump #2 running -  
water level 9-6'

Frank Harding

Monday, October 21, 1968

295th day - 71 days to follow

8:00 AM Checking station just  
#1, & #3 pump back on line  
water level 9-4" feet  
checked oil in all pumps & OK.

C. Dargan

11:30 AM Checking d. Edward.

3:20 PM Checked Station

All pumps running  
Water level 7-8'

Pump #1 hot - steam coming  
off it lost its prime - drained  
and refilled okay now.  
Shut off #3 pump  
Pumps #1 & 2 running

Clarence W. Walker

KCslip4 68027

SEA436118

Tuesday, October 22, 1968

296th day - 70 days to follow

8:00 A.M.

Checking station. water level  
9.3 turned on #3 pump all three  
running. Oct.

1:00 AM

Ed Wagon

Repaired #1 Pump for Repair  
Lyle & Dennis

3:15 P.M.

Checked Station  
Pump #1 out of service  
Pumps #2 & #3 running  
Water level 8.6'  
Turned off #3 pump (Rain)

Ed Wagon & F. Harding

Wednesday, October 23, 1968

297th day - 69 days to follow

7:50 AM Checking Station

Turned on #3 pump - #2 & #3 running  
#1 pump under repair -  
water level 7.2'

Frank Harding

10:00 AM

Replaced #1 Pump &  
Put in Service  
Lyle & Clyde

1:00 AM Checking Station

#1 pump squeaking badly - Turned off.  
Ed Wagon & F. Harding

1:15 CLEARED Station  
F. Harding  
WATER LEVEL 2.8')

3:35 PM Checking Station

Turn down #2 & #3 pumps -  
#1 pump running - (Rigid)  
WATER LEVEL 4.4'

Frank Harding

KCSlip4 68028

SEA436119

Thursday, October 24, 1968

298th day - 68 days to follow

7:50 AM Checking Station

Turned on #2 & #3 pumps -  
#1, #2 & #3 running -  
water level 7-6'

Frank Harding

1:00 PM Checking Station

Pumps #1, #2 & #3 running -  
WATER LEVEL 5-1'

Frank Harding

3:40 PM Checking Station

Shut #3 pump off -  
Pumps #1 & #2 running -  
water level 4-4'

Frank Harding

Friday, October 25, 1968

299th day - 67 days to follow

7:50 AM Checking Station

Turned on #3 pump -  
#1, #2 & #3 pumps running -  
water level 5-3'

Frank Harding

12:40 PM Checking Station

Pumps #1, #2 & #3 running -  
WATER LEVEL 3-6'

Frank Harding

2:30 PM Shut off #2 & #3 pumps

To clean bags from head works -

3:45 PM Turned #3 pump back on -  
cleaned sticks & bags from #3 &  
restricted - water level 4-8'

Frank Harding

3:45 PM Checking Station

Shut off #2 & #3 pumps -

#1 pump running & squeaking loudly -  
WATER LEVEL 4-2' (RAIN)

Frank Harding

KCslip4 68029

SEA436120

Saturday, October 26, 1968

300th day - 66 days to follow

9:30 AM Checked Station  
Pump #1 running  
Water level 7.8'  
Turned on #2 pump

Clarence W. Walker

Sunday, October 27, 1968

301st day - 65 days to follow

8:30 Checked Station  
Pump #1 running  
Water level 8.5'  
Turned on #2 pump to auto

Clarence W. Walker

3:15 PM

Checked Station  
Pumps #1 & #2 running  
Water level 7.8'  
Turned off #2 pump  
#3 is off

Clarence W. Walker

3:20 PM

Checked Station  
Pump #1 & #2 running  
Water level 7.8'  
Turned #2 pump off  
#3 pump is off

Clarence W. Walker

KCslip4 68030

SEA436121

Monday, October 28, 1968

302nd day - 64 days to follow

7:50 AM Checking Station  
Turned on pumps #2 & #3 -  
#1, #2 & #3 running -  
water level 5-9'  
Frank Harding

8:40 AM Checking Station  
Pumps #1, #2 & #3 running -  
water level 4-8'  
Frank Harding

3:45 PM Checking Station  
Shut off #2 & #3 pumps -  
#1 pump running & making high-pitched  
noise - water level 2-7'  
(rain) Frank Harding

Tuesday, October 29, 1968

303rd day - 63 days to follow

8:10 AM Checking Station  
Turned on #3 pump -  
Pumps #1, & #3 running - left  
#2 pump off because of high  
wet well - water level 8-2'  
Frank Harding

12:50 PM Checking Station  
Turned on #2 pump -  
#1, #2 & #3 running -  
water level 7-0'

Frank Harding

3:45 PM Checking Station  
Shut off pumps #2 & #3 because  
of rain - #1 pump running -  
water level 9-7'  
Frank Harding

KCSlip4 68031

SEA436122

Wednesday, October 30, 1968

304th day - 62 days to follow

7:50 A.M. Checking Station

Turned on #3 pump -  
#1 & #3 running - #2 pump off  
due to high wet well -  
water level 12-0'

Frank Harding

10:45 Checking Station

Turned on #2 pump -  
#1, #2 & #3 running -  
water level 6-0'  
#1 pump making low sharp noise -

Frank Harding

3:40 P.M. Checking Station

Shut off #2 & #3 pumps -  
pump #1 running - (min)

water level 9-4'

pump #1 still making noise -

Frank Harding

Thursday, October 31, 1968

305th day - 61 days to follow

Last Day for employers to file quarterly Social Security Tax Return  
and Wage Report, covering three previous calendar months.

7:50 A.M. Checking Station

Turned on pumps #2 & #3 -  
#1, #2 & #3 running -  
water level 6-0' -  
pump #1, still making noise -

Frank Harding

8:45 A.M. Shut off #2 & #3 pumps -  
replace packing on the pump at  
dry well head works 5 - F. Harding

11:30 A.M. restarted #2 & #3 pumps -  
water level 5-9' - F. Harding

12:40 P.M. Checking Station

Pumps #1, #2 & #3 running -  
water level 6-0'

Frank Harding

3:30 P.M. Checking Station

Shut off #2 & #3 pumps -

pump #1 running & still making  
noise - (min)

water level 8-8'

Frank Harding

KCSlip4 68032

SEA436123

Friday, November 1, 1968

306th day - 60 days to follow

7:50 AM. Checking Station  
All Saints Day

Turned on #2 & #3 pumps -  
#1, #2 & #3 running - #1 pump  
still making noise -  
water level 5-9'

Frank Harding

12:30 PM. Checking Station

Pumps #1, #2 & #3 running -  
water level 5-5'

Frank Harding

1:20 PM. Shut off pumps #2 & #3 to  
clear eggs from headworks & channel -

1:35 PM. Turned pumps #2 & #3 back on

F. Harding

3:45 PM. Checking Station

Shut #2 pump off - pumps #1 & #3  
running - water level 4-3'

Frank HARDING

Saturday, November 2, 1968

307th day - 59 days to follow

8:00 AM. Checking Station  
All Souls Day

Shut off #3 pump - Turned on  
#2 pump - pumps #1 & #2 running -  
not using 3 pump 3 because of  
high headworks wet well -  
water level 9-6'

Frank Harding

12:45 PM. Checking Station

Turned on #3 pump -  
pumps #1, #2 & #3 running -  
water level 8-4'

Frank Harding

3:40 PM. Checking Station

Shut off #2 & #3 pumps because  
of rain forecast tonight -  
pump #1 running & still making  
noise - water level 9-2'

Frank Harding

KCslip4 68033

SEA436124

Sunday, November 3, 1968

308th day - 58 days to follow

7:50 AM Checking Station

Turned on pumps #2 & #3 -  
#1, #2 & #3 running -  
water level 5-9'

Frank Harding

12:35 P.M. Checking Station

Pumps #1, #2 & #3 running -  
pump #1 still sucking noise -  
water level 5-1'

Frank Harding

3:30 P.M. Checking Station

Shut off pumps #2 & #3 -  
pump #1 running - (sucking)  
water level 4-9'

Frank Harding

Monday, November 4, 1968

309th day - 57 days to follow

7:45 AM

Checking station  
#1 Running #2 & #3 pumps  
back on line Water level 9-9"  
Ed Dargan

3:15 PM

Checked Station

All 3 pumps running  
Water 5-2'  
Shut off pumps #2 & #3

Pump #1 running

Edrence M. Walker

KCslip4 68034

SEA436125

Tuesday, November 5, 1968

310th day - 56 days to follow

Election Day

8:15 AM

Checked Station

Pump #1 running

Water level 9'

Turned pump #3 on Auto

Clarence W. Walker

3:10 PM

Checked Station

Pumps #2 + #3 running

Pump #4 off

Water level 7.6'

Turned off #3 pump

Clarence W. Walker

Wednesday, November 6, 1968

311th day - 55 days to follow

8:15 AM

#1 #2 #3 now running

water level 9' full

air level still OK.

To do along

3:15 PM

Checked Station

All three pumps running

Water Level 5.0'

Turned off Pumps #2 & #3

Clarence W. Walker

KCslip4 68035

SEA436126

Thursday, November 7, 1968

312th day - 54 days to follow

Friday, November 8, 1968

313th day - 53 days to follow

7:50 A.M. Checking Station

Turned pumps #2 & #3 on -  
Pumps #1, #2 & #3 running -  
WATER LEVEL 5-9'

Frank Harding

8:40 A.M. Checking Station

Pumps #1, #2 & #3 running -  
WATER LEVEL 5-9'

Frank Harding

3:30 P.M. Checking Station

Shut off pumps #2 & #3 (rain)  
Pump #1 running -  
WATER LEVEL 8-4'

Frank Harding

7:50 A.M. Checking Station

Turned on pumps #2 & #3 -  
Pumps #1, #2 & #3 running -  
WATER LEVEL 7-6'

Frank Harding

12:40 P.M. Checking Station

Shut off pumps #2 & #3 To  
Take rings from channel -  
Pump #1 running -

12:55 P.M. pumps #2 & #3 back on line -  
#1, #2 & #3 running -  
WATER LEVEL 6-0'

Frank Harding

3:30 P.M. Checking Station

Shut off pumps #2 & #3 - (rain)  
Pump #1 running -  
WATER LEVEL 9-6'

Frank Harding

KCSlip4 68036

SEA436127

Saturday, November 9, 1968

314th day - 52 days to follow

8:05 AM - Rain  
Checked Station  
Pumps #2 & #3 off  
Pump #1 running  
Water level 8.8'

Clarence W. Walker

Sunday, November 10, 1968

315th day - 51 days to follow

8:15 AM - Rainy  
Checked Station  
Pumps #2 & #3 off  
Pump #1 running  
Water level 10.6'

Clarence W. Walker

3:15 PM  
Checked Station  
Pump #1 running  
Water level 11.6'

Clarence W. Walker

3:20 PM  
Checked Station  
Pump #1 running  
Water level 11.8'

Clarence W. Walker

KCslip4 68037

SEA436128

Monday, November 11, 1968

316th day - 50 days to follow

Hard Rain  
8:10 AM  
Checked Station  
Pumps #2 & #3 off  
Pump #1 running  
Water level 11.4'

Clarence H. Walker

3:15 PM  
Checked Station  
Pumps #2 & #3 off  
Pump #1 running  
Water level 12.2'

Clarence H. Walker

Tuesday, November 12, 1968

317th day - 49 days to follow

7:50 AM Checking Station  
Turned on pump #2 -  
Pumps #1 & #2 running - #3 off -  
WATER LEVEL 12.4' -  
Frank Harding

12:40 PM Checking Station  
Pumps #1 & #2 running -  
Pump #3 off - WATER LEVEL 10.7'  
Frank Harding

3:30 PM Checking Station  
Shut off #2 pump - #3 off -  
Pump #1 running -  
WATER LEVEL 10.8'  
Frank Harding

KCslip4 68038

SEA436129

Wednesday, November 13, 1968

318th day - 48 days to follow

7:50 AM Checking Station  
Turned on pumps #2 & #3 -  
Pumps #1, #2 & #3 running -  
water level 9-3'

Frank Harding

12:40 PM Checking Station  
Pumps #1, #2 & #3 running -  
water level 5-4'

Frank Harding

3:30 PM  
Checked Station  
All pumps running  
Water level 5-4'  
Turned off pumps #2 & #3

Edrence W. Walker

Thursday, November 14, 1968

319th day - 47 days to follow

7:50 AM Checking Station  
Turned on pumps #2 & #3 -  
Pumps #1, #2 & #3 running -  
water level 7-5'

Frank Harding

3:25 PM - CHECKING STATION

ALL PUMPS RUNNING

WATER LEVEL 5-4'

TURNED OFF PUMPS #2, #3

Dave Rooday

KC Slip 4 68039

SEA436130

Friday, November 15, 1968

320th day - 46 days to follow

7:15 A.M. Checking Station  
Tubes out pumps #2 & #3 -  
Pumps #1, #2 & #3 running -  
water level 5-9'  
Frank Harding

11:00 A.M. Shut down pumps #2 & #3  
to clean rags from channel -  
11:20 pumps #2 & #3 back on line  
Frank Harding

12:45 P.M. Checking Station  
Pumps #1, #2 & #3 running -  
water level 5-5'

1:45 P.M. Shut off pumps #2 & #3 because  
of high wet well - pump #1 working  
less noisy - Frank Harding  
2:00 P.M. Shut down #1 pump, started  
#3 pump - water level 9-2'

3:30 P.M. Checking Station  
Pumps #1 & #2 off - #3 running -  
water level 9-1'  
Frank Harding

Saturday, November 16, 1968

321st day - 45 days to follow

3:30 A.M. Checking Station  
#3 pump running - #1, #2 pumps off  
water level 9.0'  
TURNED #2 PUMP - #2, #3 running  
Dave Roddey

3:30 P.M. Checking Station  
PUMPS #2, #3 running - #1 off  
WATER LEVEL 7.2'  
TURNED #3 PUMP OFF FOR NIGHT  
Dave Roddey

KCSlip4 68040

SEA436131

Sunday, November 17, 1968

322nd day - 44 days to follow

8:10 A.M.

CHECKING STATION

PUMP #2 RUNNING - #1 & #3 OFF

WATER LEVEL - 9.0'

TURNED #3 PUMP ON - #2 & #3 Running.

Dave Rodey

Monday, November 18, 1968

323rd day - 43 days to follow

7:50 AM Checking Station

Turned on pumps #1 & #3 -

Pumps #1, #2 & #3 running -

WATER LEVEL 5-7'

Frank Harming

3:30 P.M. Checking Station

PUMPS #2, #3 RUNNING, #1 OFF

WATER LEVEL - 7.2'

TURNED #3 PUMP OFF FOR NITE

Dave Rodey

12:50 PM Checking Station

Pumps #1, #2 & #3 running

Pump #1 making high-pitched noise -

WATER LEVEL 5-2'

Frank Harming

3:35 P.M. Checking Station

Shut off pumps #1 & #3 -

pump #3 making noise -

pump #2 running -

WATER LEVEL 8-9'

Frank Harming

KC Slip 4 68041

SEA436132

Tuesday, November 19, 1968

324th day - 42 days to follow

7:50 AM Checking Station  
Turned on pumps #1, #2 & #3 -  
Pumps #1, #2 & #3 running -  
WATER LEVEL 5-6'  
Frank Harding

12:45 PM Checking Station  
Pumps #1, #2 & #3 running -  
WATER LEVEL 5-6'  
Frank Harding

2:50 PM Checking Station  
Shut off pumps #1 & #2 -  
Pump #3 running -  
WATER LEVEL 5-3'  
Frank Harding

Wednesday, November 20, 1968

325th day - 41 days to follow

7:50 AM Checking Station  
Turned on pump #1 -  
Pumps #1 & #3 running -  
Pump #2 off because of high  
wet well -  
WATER LEVEL 11-6'  
Frank Harding

12:50 PM Checking Station  
Turned on pump #3 -  
Pumps #1, #2 & #3 running  
WATER LEVEL 6-2'  
Pump #1 making noise!  
Frank Harding

3:25 PM Checking Station  
PUMPS #1, #2, #3 RUNNING  
WATER LEVEL - 5.8'  
SHUT OFF PUMPS #1, #2 FOR WHILE  
PUMP #3 RUNNING  
DAN RODDY

KCSlip4 68042

SEA436133

Thursday, November 21, 1968

326th day - 40 days to follow

Friday, November 22, 1968

327th day - 39 days to follow

President Kennedy's Assassination

7:50 A.M. Checking Station

TURNED ON PUMPS #1 & #2 -  
PUMPS #1, #2 & #3 RUNNING -  
WATER LEVEL 5-8'

Frank Harding

11:30 A.M. Checking Station

PUMPS #1, #2, #3 RUNNING  
WATER LEVEL - 5.8'

Dave Roddy

12:40 P.M. Checking Station

Shut off pumps #2 & #3 to put new  
packing in #2 pump at head works -

1:30 P.M. leaving pumps #2 & #3 off  
because of head works high wet well  
WATER LEVEL 12-8'

Frank Harding

3:40 P.M. Checking Station

PUMPS #2 & #3 OFF - #1 RUNNING  
WATER LEVEL 14-6'  
High head works wet well &  
more rain forecast tonight.

Frank Harding

7:50 A.M. Checking Station

PUMPS #2 & #3 BACK ON LINE -  
#1, #2 & #3 RUNNING -  
WATER LEVEL 9-8'

Frank Harding

9:30 AM. PUMPS #2 & #3 OFF LINE TO  
CLEAR EGGS FROM CHANNEL -

9:45 A.M. #2 & #3 BACK ON LINE -  
WATER LEVEL 7-6'

Frank Harding

12:45 P.M. Checking Station

PUMPS #1, #2 & #3 RUNNING -  
WATER LEVEL 5-8'

Frank Harding

3:30 P.M. Checking Station

PUMPS #1, #2, #3 RUNNING

WATER LEVEL - 6.0'

TURNED OFF #1, #2 PUMPS FOR NITE

Dave Roddy

KCSlip4 68043

SEA436134

Saturday, November 23, 1968

328th day - 38 days to follow

7:50 AM. Checking Station

Pump #3 running - #1 & #2 back  
on line - water level 8-7'

Frank Harding

12:50 PM. Checking Station

Pumps #1, #2 & #3 running -  
#1 pump making scraping noise -  
water level 5-9'

Frank Harding

3:30 PM. Checking Station

Shut off pumps #1 & #3 -  
pump #2 running -  
water level 9-1'  
rain forecast

Frank Harding

Sunday, November 24, 1968

329th day - 37 days to follow

7:50 AM. Checking Station

Pump #2 running - #1 & #3 back  
on line - water level 5-6'

Frank Harding

12:50 PM. Checking Station

Pumps #1, #2 & #3 running -  
water level 6-0

Frank Harding

3:40 PM. Checking Station

Shut off pumps #1 & #2 -  
pump #3 running -  
pump #1 still making noise -  
water level 9-2' (rain)

Frank Harding

KCslip4 68044

SEA436135

Monday, November 25, 1968

330th day - 36 days to follow

7:40 AM CHECKING STATION  
PUMPS #3 RUNNING. #1, #2 OFF  
WATER LEVEL - 9.0'  
TURNED PUMPS #1, #2 ON. #1 PUMP VERY LOUD & SLOW.  
PUMPS #1, #2, #3 RUNNING. SWEEP FLOOR.  
DAVE RODDY

12:45 P.M. CHECKING STATION  
PUMPS #1, #2, #3 RUNNING  
WATER LEVEL - 6.0'  
DAVE RODDY

3:30 P.M. CHECKING STATION  
PUMPS #1, #2, #3 RUNNING  
WATER LEVEL - 6.0'  
PUMPS #1, #2 OFF FOR NITE  
DAVE RODDY

Tuesday, November 26, 1968

331st day - 35 days to follow

8:20 A.M. CHECKING STATION  
PUMPS #3 RUNNING - #1, #2 OFF  
WATER LEVEL - 9.0'  
TURNED ON PUMPS #1, #2  
PUMPS #1, #2, #3 RUNNING.  
DAVE RODDY

12:35 P.M. CHECKING STATION  
PUMPS #1, #2, #3 RUNNING  
WATER LEVEL 6.0'  
DAVE RODDY

3:30 P.M. CHECKING STATION  
PUMPS #1, #2, #3 RUNNING  
WATER LEVEL - 6.1'  
PUMPS #2, #3 OFF FOR NITE  
DAVE RODDY

KCSlip4 68045

SEA436136

Wednesday, November 27, 1968

332nd day - 34 days to follow

Thursday, November 28, 1968

333rd day - 33 days to follow

7:50 A.M. Checking Station

Pump #1 running - #2 & #3

back on line - WATER LEVEL 7-7'

Frank Harding

Thanksgiving Day

7:50 A.M. Checking Station

Pumps #1, #2 & #3 back on line -

#1, #2 & #3 running -

WATER LEVEL 5-9'

Frank Harding

12:50 P.M. CHECKING STATION

PUMPS #1, #2, #3 RUNNING

WATER LEVEL - 6-0'

DAVE RODNEY

12:50 P.M. Checking Station

Pumps #1, #2 & #3 running -

WATER LEVEL 6-0'

Frank Harding

3:30 P.M. CHECKING STATION

PUMPS #1, #2, #3 RUNNING

WATER LEVEL - 6-0'

PUMPS #1, #3 OFF FOR NITE.

PUMP #2 RUNNING.

DAVE RODNEY

3:40 P.M. Checking Station

Shut off pumps #1 & #2 -

Pump #3 running -

WATER LEVEL 9-0'

Frank Harding

4:00 P.M. Put #2 pump back on

line - low headwork wet well-

WATER LEVEL 7-2'

F. Harding

KCslip4 68046

SEA436137

Friday, November 29, 1968

334th day - 32 days to follow

8:00 A.M. Checking Station  
Pump #1 back on line.  
Pumps #1, #2 & #3 running -  
WATER LEVEL 7-2'

Frank Harding

10:30 A.M. Shut off pumps #2 & #3 to  
Take bags from channel -

Frank Harding

10:51 A.M. Took bags from channel.

WATER LEVEL 11.8'

Turned on #2 pump

Pumps #1 & 2, Running

Dave Roddey

12:50 P.M. Checking Station

Shut off #3 pump - #2 & #3 off -  
pump #1 running - water level 13-7'

High wet well at basement

Frank Harding

3:40 P.M. Checking Station

Pump #1 running - #2 & #3 off  
for the night (rain)  
WATER LEVEL 13-8'

Frank Harding

Saturday, November 30, 1968

335th day - 31 days to follow

7:50 A.M. Checking Station

Pumps #3 & #3 back on line -  
#1, #2 & #3 running - WATER LEVEL 9-8'  
pump #1 making noise -

Frank Harding

11:45 A.M. Checking Station

Pumps #1, #2 & #3 running  
WATER LEVEL 6-0'

Frank Harding

3:20 P.M. Checked Station

All pumps running  
Water level 8'

turned off #2 & #3 pumps.

Lawrence H. Walker

KCslip4 68047

SEA436138

Sunday, December 1, 1968

336th day - 30 days to follow

First Sunday in Advent

8:30 AM

Checking Station

Pump #1 running

Pumps #2 & #3 off

Water level 9.4'

Monday, December 2, 1968

337th day - 29 days to follow

8:35 AM. Checking Station

Pumps #2 & #3 back on line -

#1, #2 & #3 running -

WATER LEVEL 9.2'

Frank Harding

#1 pump very low noise F.H.

Clarence W. Walker

12:45 PM Checking Station

Pumps #1, #2 & #3 running -

WATER LEVEL 5.4'

Frank Harding

9:20 PM

Checking Station

Pump #1 running

Pumps #2 & #3 off

Water level 13.4'

Clarence W. Walker

3:30 PM Checking Station

Shut off pump #1 & #3 -

pump #2 running -

WATER LEVEL 9.0'

pump #1 working noise

Frank Harding

KCslip4 68048

SEA436139

Tuesday, December 3, 1968

338th day - 28 days to follow

7:50 AM Checking Station

Changer less from #2 to #1 -  
pump #1 running - #2 & #3 off  
because of high head work  
wet well - water level 13-7'

Frank Harding

12:40 P.M. Checking Station

Pump #1, running & making noise -  
Pump #2 & #3 off,  
water level 13-8'

Frank Harding

1:00 P.M. Checking station

Pump #1 - running, and noisy but it  
will not pump

Started #2 pump

water level 13'9"

Ed Dorgan

3:30 P.M. Checking Station

Shut off #1 pump - #1 & #2 off -  
pump #3 running -

WATER LEVEL 13-9'

Frank Harding

Wednesday, December 4, 1968

339th day - 27 days to follow

8:00 AM Checking Station

Pumps #1, #2 back on line -  
#1, #3 & #3 running -  
WATER LEVEL 10-2'

Frank Harding

12:45 P.M. Checking Station

Pumps #1, #2 & #3 running -  
water level 9-2'

#1 pump making noise

Frank Harding

3:40 P.M. Checking Station

Shut pumps #1 & #3 -

pump #2 running -

WATER LEVEL 9-2'

Frank Harding

KCslip4 68049

SEA436140

Thursday, December 5, 1968

340th day - 26 days to follow

7:50 AM. Checking Station

Pumps #1 & #3 back on line -  
#1, #2 & #3 running -

WATER LEVEL 10-0'

Frank Harding

12:45 PM. Checking Station

Pumps #1, #2 & #3 running -  
WATER LEVEL 5-8'

#1, pumps hissing noise -

Frank Harding

3:40 PM. Checking Station

Shut off pumps #1 & #2 -  
pump #3 running -

WATER LEVEL 9-2'

Frank Harding

Friday, December 6, 1968

341st day - 25 days to follow

8:15 AM. Checking Station

Pumps #1 & #2 back on line -

#1, #2 & #3 running - WATER LEVEL 9-4'

Frank Harding

1:40 PM. Shut off pumps #2 & #3 to

clear rags from channel -

2:00 PM. Pumps #2 & #3 back on line -

WATER LEVEL 6-0'

Frank Harding

3:15 PM. Checking Station

Shut off pumps #1 & #3 -

pump #2 running -

WATER LEVEL 9-2'

Frank Harding

KCslip4 68050

SEA436141

Saturday, December 7, 1968

342nd day - 24 days to follow

7:15 A.M. CHECKING STATION

PUMP #2 RUNNING.

WATER LEVEL - 12.4'

TURNED PUMPS #1, #3 ON FOR DAY. 1, 2, 3 ON.

DAVE RODDEY

4:00 P.M. CHECKING STATION

PUMPS #1, #2, #3 RUNNING

WATER LEVEL - 6.0'

PUMPS #2, #3 OFF FOR NIGHT.

DAVE RODDEY

Sunday, December 8, 1968

343rd day - 23 days to follow

Feast of Immaculate Conception

Second Sunday of Advent

7:20 A.M. CHECKING STATION

PUMP #1 RUNNING

WATER LEVEL 72.6'

LEFT PUMPS #2, #3 OFF BECAUSE OF HIGH WATER  
AT HEADWORKS OVERWELL.

DAVE RODDEY

4:15 P.M. CHECKING STATION

PUMP #1 RUNNING

WATER LEVEL - 13.6'

PUMPS #2, #3 OFF FOR NIGHT.

DAVE RODDEY

KCslip4 68051

SEA436142

Monday, December 9, 1968

344th day - 22 days to follow

7:55 AM Checking Station

Pumps #2 & #3 back on lines -

#1, #2 & #3 running water level 10-4'

Frank Herring

11:15 AM Shut off #1 pump due to  
high wet well - Frank Herring  
water level 11-2'

12:50 PM Checking Station

Pumps #2 & #3 running - #1 off -  
water level 12-0'

Frank Herring

3:45 PM Checking Station

Shut off #3 pump - #1 & #3 off

Pump #2 running

water level 13-5'

Frank Herring

Tuesday, December 10, 1968

345th day - 21 days to follow

7:50 AM Checking Station

Turned on #3 pump - #2 & #3 running -  
pump #1 off because of high wet well  
water level 12-4'

Frank Herring

3:35 PM

Checking Station

Pump #2 & 3 running

Pump #1 off

Water level 12-2'

Shut off pump #3

Clarence W. Walker

KCSlip4 68052

SEA436143

Wednesday, December 11, 1968

346th day - 20 days to follow

8:00 A.M. Checking Station

Shut down #2 pump - all pumps off  
To put new packing in #2 sewage  
pump - water level 14-4'

Frank Harding

11:01 A.M. PUT #1 PUMP ON LINE. #2, #3

PUMPS OFF TILL MORNING CHECKS #2 SEWAGE

PUMP. WATER LEVEL 14-8'

DAVE RODDICK

3:50 Checking Station

Shut off #1 pump - #1 & #3 off -  
pump #2 back on line -  
water level 13-8'

Frank Harding

9:00 P.M. Checking T. Morgan

Thursday, December 12, 1968

347th day - 19 days to follow

8:00 A.M. Checking Station

Change leak from #2 to #3 pump -  
pumps #1 & #2 off (#2 sewage  
pump at headwork down for  
repair - water level 13-8'

Frank Harding

1:50 P.M.

Checking station 13-8' out

T. Morgan

1:00 P.M. Cleanup - Frank Harding

3:30 P.M. CHECKING STATION

pump #3 running, #1 & #2 off  
WATER LEVEL 13-8'

DAVE RODDICK

KCslip4 68053

SEA436144

Friday, December 13, 1968

348th day - 18 days to follow

7:50 A.M. Checking Station

Pumps #1, #2 back on line -  
#1, #2 & #3 running - water level 9-8'  
Frank Harding

8:30 P.M. Checking Station

PUMPS #1, #2, #3 RUNNING  
WATER LEVEL - 4-4'  
PUMPS #1, #2 OFF FOR NIGHT, #1 ON  
D. ROSE RODDEY

Saturday, December 14, 1968

349th day - 17 days to follow

8:00 A.M. Checking Station

Pumps #1 & #2 back on line -  
#1, #2 & #3 running -  
water level 9-6'

Frank Harding

12:45 P.M. Checking Station

Pumps #1, #2 & #3 running -  
water level 4-9'

Frank Harding

1:25 P.M. took pumps #2 & #3 off line  
To dredge channel -

1:40 P.M. pumps #2 & #3 back on line -  
water level 5-0'

F. Harding

3:40 P.M. Checking Station

Shut down pumps #1 & #3 (RAIN)  
pump #2 running -  
water level 5-1'

Frank Harding

KCSlip4 68054

SEA436145

Sunday, December 15, 1968

350th day - 16 days to follow

7:50 A.M. Checking Station

Pumps #1 & #3 back on line  
#1, #2 & #3 running.  
WATER LEVEL 8-6'

Frank Harding

12:40 P.M. Checking Station

Pumps #1, #3 & #3 running  
WATER LEVEL 4-9'

Frank Harding

3:30 P.M. Checking Station

Shut off pumps #1 & #2 (RAIN)  
pump #3 running -  
WATER LEVEL 5-8'

Frank Harding

Monday, December 16, 1968

351st day - 15 days to follow

8:15 A.M.

First Day of Chanukah

CHECKING STATION

PUMP #3 RUNNING

WATER LEVEL - 13.6

TURNED ON PUMP #1, #2 - #1, #2, #3 NOW RUNNING

DAVE RODDY

3:30 A.M. CHECKING STATION

PUMPS #1, #2, #3 RUNNING

WATER LEVEL - 4.8'

TURNED PUMPS #2, #3 OFF FOR NITE. #1 ON.

DAVE RODDY

KCslip4 68055

SEA436146

Tuesday, December 17, 1968

352nd day - 14 days to follow

8:00 AM. Checking station.  
Water level 13.5" feet  
#1, #2 & #3 running  
Put #3 back on line  
Checked all four east pumps

C. W. Walker

12:45 PM. Checking station  
water level 5.2" feet

C. W. Walker

3:00 PM  
Checked Station  
All 3 pumps running  
Water level 5.0'  
Turned off #2 & #3 pumps

Clarence W. Walker

Wednesday, December 18, 1968

353rd day - 13 days to follow

8:00 AM  
Checking station  
water level 13.5" feet  
Drowning and heaving  
#1 & #2 pumps operating  
#3 slowly due to heavy rain

C. W. Walker

3:22 PM  
Checking station  
Pumps #1 & #2 running  
Water level 13.8'  
Turned off #2 & #3

Clarence W. Walker

KCslip4 68056

SEA436147

Thursday, December 19, 1968

354th day - 12 days to follow

7:50 A.M. Checking Station  
Turned on pumps #2 & #3  
Pumps #1, #3 & #3 running  
#1 making noise -  
WATER LEVEL 10-0'  
Frank Harding

12:40 P.M. Checking Station  
Shut off #1 pump because of  
high wet well - also is making noise -  
Pumps #2 & #3 running -  
WATER LEVEL 4-5'  
Frank Harding

3:40 P.M. Checking Station  
Shut off #3 pump - #1 & #2 off -  
Pump #3 running -  
WATER LEVEL 11-6'  
Frank Harding

Friday, December 20, 1968

355th day - 11 days to follow

8:10 A.M. Checking Station  
Pumps #1 & #2 back on line -  
#1, #2 & #3 running -  
WATER LEVEL 10-2'  
Frank Harding

12:40 P.M. Turned off pumps #1 & #2  
to clean bags from chamber -  
12:05 P.M. Pumps #1 & #3 back on line -  
all 3 pumps running -  
WATER LEVEL 5-7'  
Pump #1 making noise!  
Frank Harding

12:10 P.M. Insurance brokers, insuring Metro  
facilities, here on inspection  
Frank Harding

3:40 P.M. Checking Station  
Shut off pumps #1 & #2 -  
Pump #2 running -  
Pump #1 making a great deal  
of noise -  
WATER LEVEL 10-0'  
Frank Harding

KCSlip4 68057

SEA436148

Saturday, December 21, 1968

356th day - 10 days to follow

5:00 AM Checking Station

Pumps #1 & #3 back on line  
All 3 pumps running -  
WATER LEVEL 10-4'

Frank Hardwig

12:40 PM Checking Station

Pumps #1, #2 & #3 running  
#1 working noise -  
WATER LEVEL 4-4'

Frank Hardwig

3:30 PM Checking Station

Shut off pumps #2 & #3 -  
Pump #1 running (working noise)  
WATER LEVEL 4-9'

Frank Hardwig

Sunday, December 22, 1968

357th day - 9 days to follow

Fourth Sunday in Advent

7:50 AM Checking Station

Pumps #2 & #3 back on line -  
All 3 pumps running -  
WATER LEVEL 11-4'

Frank Hardwig

12:40 PM Checking Station

Pumps #1, #2 & #3 running  
pump #1 working noise -  
WATER LEVEL 4-8'

Frank Hardwig

3:45 PM Checking Station

Shut off pumps #1 & #3 -  
Pump #2 running -  
WATER LEVEL 5-0'

Frank Hardwig

KCSlip4 68058

SEA436149

Monday, December 23, 1968

358th day - 8 days to follow

7:50 A.M. Checking Station

Pumps #1 & #3 back on line -  
all 3 pumps running -  
WATER LEVEL 12.6'

Frank Haroing

12:50 P.M. Checking Station

Pumps #1, #2 & #3 running -  
#1 pump making noise -  
WATER LEVEL 9.1'

Frank Haroing

3:45 P.M. Checking Station

Shut off pumps #1 & #2 run -  
Pump #3 running -  
WATER LEVEL 12.4'

Frank Haroing

Tuesday, December 24, 1968

359th day - 7 days to follow

8:10 A.M. Checking Station

PUMP #3 running

WATER LEVEL - 16.4'

TURNED PUMPS #1, #2 ON. #1, #2, #3 now Running.

DAVE RODDEY

11:35AM. CHECKING STATION

PUMPS #1, #2, #3 RUNNING

TURNED #3 PUMP OFF.

WATER LEVEL - 12.2'

DAVE RODDEY

2:55PM. CHECKING STATION

TURNED OFF #2 PUMP. #3 ON

#1 PUMP RUNNING

WATER LEVEL - 13.6'

DAVE RODDEY

KCslip4 68059

SEA436150

Wednesday, December 25, 1968

360th day - 6 days to follow

Christmas  
8:00 A.M. Checking station  
PUMPS #1 RUNNING  
WATER LEVEL - 94.6'  
TURNED #2 PUMPS ON - #1, #2 Running, #3 OFF  
DAVE RODDEY

3:20 P.M. Checking station  
PUMPS #1, #2 Running - #3 OFF  
WATER LEVEL - 11.0'  
TURNED #2 PUMP OFF FOR NITE  
DAVE RODDEY

Thursday, December 26, 1968

361st day - 5 days to follow

5:10 A.M. Checking Station  
Turned on pump #2 & #3 -  
Pumps #1, #2 & #3 running -  
Pump #1 making noise -  
WATER LEVEL 9-6'

Frank Harding  
Checking station - 1:20 P.M.  
PUMPS #1, #2, #3 RUNNING  
WATER LEVEL - 4.4'  
DAVE RODDEY

3:35 P.M. CHECKING STATION  
PUMPS #1, #2, #3 RUNNING.  
WATER LEVEL - 4.2'  
PUMPS #2, #3 OFF FOR NITE.  
DAVE RODDEY

KCslip4 68060

SEA436151

Friday, December 27, 1968

362nd day - 4 days to follow

11:30AM. CHECKING STATION  
PUMPS #1 RUNNING, #2, #3 OFF  
WATER LEVEL - 14.4'  
TURNED ALL PUMPS ON  
DAVE RODDIE

5:40 PM. CHECKING  
PUMPS #1, #2, #3 RUNNING  
WATER LEVEL - 4.8'  
PUMPS #2, #3 OFF FOR NITE  
DAVE RODDIE

Saturday, December 28, 1968

363rd day - 3 days to follow

8:00AM. CHECKING STATION  
PUMPS #1 RUNNING  
WATER LEVEL - 12.4'  
ALL PUMPS ON  
DAVE RODDIE

3:30P.M. CHECKING STATION  
PUMPS #1, #2, #3 RUNNING  
WATER LEVEL - 4.4'  
PUMPS #1, #2 OFF FOR NITE.  
DAVE RODDIE

KCSlip4 68061

SEA436152

Sunday, December 29, 1968

365th day - 1 day to follow

8:10 A.M. CHECKING STATION

PUMP #1 RUNNING

WATER LEVEL - 9.0'

ALL PUMPS NOW ON

Dave Roddey

3:25 P.M. CHECKING STATION

ALL PUMPS RUNNING

WATER LEVEL - 9.8'

PUMPS #1, #2 ON FOR NITE.

Dave Roddey

Monday, December 30, 1968

365th day - 1 day to follow

8:05 AM

Checking Station

Put all 3 pumps on service  
water level 9.4' feet

Checked oil level

#1 pump squeaking - will report  
to maintenance.

E.W. Morgan

3:30 PM

Checking station

#3 only on service for the nite.  
water level 9.0 feet.

E.W. Morgan

HAPPY NEW YEAR!

KCSlip4 68062

SEA436153

Tuesday, December 31, 1968

### Memoranda

1145

### **366th day – The last day**

KCSlip4 68063

SEA436154